

Project 2007-11 Disturbance Monitoring

VRF and VSL Justifications

This document provides the drafting team's justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in PRC-002-2 – Disturbance Monitoring and Reporting Requirements.

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined by the ERO Sanctions Guidelines.

The Disturbance Monitoring and Reporting Requirements Standard Drafting Team applied the following NERC criteria and FERC Guidelines when proposing VRFs and VSLs for the requirements under this project:

NERC Criteria –VRFs

High Risk Requirement

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

Medium Risk Requirement

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.

Lower Risk Requirement

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

FERC VRF Guidelines

Guideline (1) – Consistency with the Conclusions of the Final Blackout Report

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

Guideline (2) – Consistency within a Reliability Standard

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

Guideline (3) – Consistency among Reliability Standards

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

Guideline (4) – Consistency with NERC's Definition of the Violation Risk Factor Level

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC's definition of that risk level.

Guideline (5) – Treatment of Requirements that Co-mingle More Than One Obligation

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

VRF and VSL Justifications – PRC-002-2, R1	
Proposed VRF	Lower
NERC VRF Discussion	R1 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R1 establishes the list of Sequence of Events Recordings and Fault Recordings that is consistent with FERC guideline G1, Recommendation 12 of the Blackout Report.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement calls for establishing a list of BES bus locations for Sequence of Events Recording and Fault Recording using the selection procedure in Attachment 1. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish the list of BES bus locations for Sequence of Events Recording and Fault Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R1 contains only one objective which is to establish a list of BES bus locations for Sequence of Events Recording and Fault Recording and to review the list every 5-calendar years. Since the requirement has only one objective, only one VRF was assigned.

VRF and VSL Justifications – PRC-002-2, R1	
Proposed Lower VSL	<p>The Transmission Owner identified the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 for more than 80% but less than 100% of the required BES buses that they own.</p> <p>OR</p> <p>The Transmission Owner evaluated the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 but was late by 30-calendar days or less.</p> <p>OR</p> <p>The Transmission Owner as directed by Requirement R1, Part 1.2 was late in notifying the other owners by 10-calendar days or less.</p>
Proposed Moderate VSL	<p>The Transmission Owner identified the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 for more than 70% but less than or equal to 80% of the required BES buses that they own.</p> <p>OR</p> <p>The Transmission Owner evaluated the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 but was late by greater than 30-calendar days and less than or equal to 60-calendar days.</p> <p>OR</p> <p>The Transmission Owner as directed by Requirement R1, Part 1.2 was late in notifying the other owners by greater than 10-calendar days but less than or equal to 20-calendar days.</p>
Proposed High VSL	<p>The Transmission Owner identified the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 for more than 60% but less than or equal to 70% of the required BES buses that they own.</p> <p>OR</p> <p>The Transmission Owner evaluated the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 but was late by greater than 60-calendar days and less than or equal to 90-calendar days.</p> <p>OR</p> <p>The Transmission Owner as directed by Requirement R1, Part 1.2 was late in notifying the other owners by greater than 20-calendar days but less than or equal to 30-calendar days.</p>

VRF and VSL Justifications – PRC-002-2, R1	
Proposed Severe VSL	<p>The Transmission Owner identified the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 for less than or equal to 60% of the required BES buses that they own.</p> <p>OR</p> <p>The Transmission Owner evaluated the BES buses as directed by Requirement R1, Part 1.1 or Part 1.3 but was late by greater than 90-calendar days.</p> <p>OR</p> <p>The Transmission Owner as directed by Requirement R1, Part 1.2 was late in notifying one or more other owners by greater than 30-calendar days.</p>
<p>FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments</p>	<p>Guideline 2a: The VSL assignment is for R1 is not binary.</p> <p>Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R1	
that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R2	
Proposed VRF	Lower
NERC VRF Discussion	R2 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R2 provides criteria for Sequence of Events Recording which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard This requirement does not have parts.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes criteria for Sequence of Events Recording selected in R1, Attachment 1. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish criteria for Sequence of Events Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R2 contains only one objective which is to establish criteria for Sequence of Events Recording. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	Each Transmission or Generator Owner as directed by Requirement R2 had more than 80% but less than 100% of the total SER data for circuit breaker position (open/close) for each of the circuit breakers at the bus locations as per Requirement R2.
Proposed Moderate VSL	Each Transmission or Generator Owner as directed by Requirement R2 had more than 70% but less than or equal to 80% of the total SER

VRF and VSL Justifications – PRC-002-2, R2	
	data for circuit breaker position (open/close) for each of the circuit breakers at the bus locations as per Requirement R2.
Proposed High VSL	Each Transmission or Generator Owner as directed by Requirement R2 had more than 60% but less than or equal to 70% of the total SER data for circuit breaker position (open/close) for each of the circuit breakers at the bus locations as per Requirement R2.
Proposed Severe VSL	Each Transmission or Generator Owner as directed by Requirement R2 for less than or equal to 50% of the total SER data for circuit breaker position (open/close) for each of the circuit breakers at the bus locations as per Requirement R2.
<p>FERC VSL G1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 2a:</p> <p>The VSL assignment is for R2 is not binary.</p> <p>Guideline 2b:</p> <p>The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R2	
<p>FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.</p>
<p>FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>	<p>Proposed VSLs are based on a single violation and not a cumulative violation methodology.</p>
<p>FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs</p>	<p>Non CIP</p>
<p>FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence</p>	<p>Non CIP</p>

VRF and VSL Justifications – PRC-002-2, R3	
Proposed VRF	Lower
NERC VRF Discussion	R3 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R3 provides criteria for Fault Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes criteria for Fault Recording selected in R1, Attachment 1. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish criteria for Fault Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R3 contains only one objective which is to establish criteria for Fault Recording. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner had FR data as directed by Requirement R3, Parts 3.1 and 3.2 that covers more than 80% but less than 100% of the total set of required electrical quantities, which is the product of the total number of monitored BES Elements and the number of specified electrical quantities per each Element.
Proposed Moderate VSL	The Transmission Owner or Generator Owner had FR data as directed by Requirement R3, Parts 3.1 and 3.2 that covers more than 70% but less than or equal to 80% of the total set of required electrical quantities, which is the product of the total number of monitored BES

VRF and VSL Justifications – PRC-002-2, R3	
	Elements and the number of specified electrical quantities per each Element.
Proposed High VSL	The Transmission Owner or Generator Owner had FR data as directed by Requirement R3, Parts 3.1 and 3.2 that covers more than 60% but less than or equal to 57% of the total set of required electrical quantities, which is the product of the total number of monitored BES Elements and the number of specified electrical quantities per each Element.
Proposed Severe VSL	The Transmission Owner or Generator Owner had FR data as directed by Requirement R3, Parts 3.1 and 3.2 that covers less than or equal to 60% of the total set of required electrical quantities, which is the product of the total number of monitored BES Elements and the number of specified electrical quantities per each Element.
<p>FERC VSL G1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 2a:</p> <p>The VSL assignment is for R4 is not binary.</p> <p>Guideline 2b:</p> <p>The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R3	
<p>FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.</p>
<p>FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>	<p>Proposed VSLs are based on a single violation and not a cumulative violation methodology.</p>
<p>FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs</p>	<p>Non CIP</p>
<p>FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence</p>	<p>Non CIP</p>

VRF and VSL Justifications – PRC-002-2, R4	
Proposed VRF	Lower
NERC VRF Discussion	R4 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R4 provides criteria for Fault Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes criteria for Fault Recordings selected in R1, Attachment 1. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish criteria for Fault Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R4 contains only one objective which is to establish criteria for Fault Recording. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner had FR data that meets more than 80% but less than 100% of the total recording properties as specified in Requirement R4.
Proposed Moderate VSL	The Transmission Owner or Generator Owner had FR data that meets more than 70% but less than or equal to 80% of the total recording properties as specified in Requirement R4.

VRF and VSL Justifications – PRC-002-2, R4	
Proposed High VSL	The Transmission Owner or Generator Owner had FR data that meets more than 60% but less than or equal to 70% of the total recording properties as specified in Requirement R4.
Proposed Severe VSL	The Transmission Owner or Generator Owner had FR data that meets less than or equal to 60% of the total recording properties as specified in Requirement R4.
<p>FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
<p>FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 2a: The VSL assignment is for R5 is not binary.</p> <p>Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>
<p>FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.

VRF and VSL Justifications – PRC-002-2, R4	
<p>FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>	<p>Proposed VSLs are based on a single violation and not a cumulative violation methodology.</p>
<p>FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs</p>	<p>Non CIP</p>
<p>FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence</p>	<p>Non CIP</p>

VRF and VSL Justifications – PRC-002-2, R5	
Proposed VRF	Lower
NERC VRF Discussion	R5 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R5 establishes the list of Dynamic Disturbance Recordings that is consistent with FERC guideline G1, Recommendation 12 of the Blackout Report.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement calls for identifying BES Elements for Dynamic Disturbance Recording. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to identify BES Elements for Dynamic Disturbance Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R5 contains only one objective which identifies BES Elements within specified criteria and to review the list every 5-calendar years. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Responsible Entity identified the Elements for which DDR data is required as directed by Requirement R5 for more than 80% but less than 100% of the required Elements included in Part 5.1. OR

VRF and VSL Justifications – PRC-002-2, R5	
	<p>The Responsible Entity identified the Elements for DDR as directed by Requirement R5, Part 5.1 or Part 5.4 but was late by 30-calendar days or less.</p> <p>OR</p> <p>The Responsible Entity as directed by Requirement R5, Part 5.3 was late in notifying the owners by 10-calendar days or less.</p>
Proposed Moderate VSL	<p>The Responsible Entity identified the Elements for which DDR is required as directed by Requirement R5 for more than 70% but less than or equal to 80% of the required Elements included in Part 5.1.</p> <p>OR</p> <p>The Responsible Entity identified the Elements for DDR as directed by Requirement R5, Part 5.1 or Part 5.4 but was late by greater than 30-calendar days and less than or equal to 60-calendar days.</p> <p>OR</p> <p>The Responsible Entity as directed by Requirement R5, Part 5.3 was late in notifying the owners by greater than 10-calendar days but less than or equal to 20-calendar days.</p>
Proposed High VSL	<p>The Responsible Entity identified the Elements for which DDR data is required as directed by Requirement R5 for more than 60% but less than or equal to 70% of the required Elements included in Part 5.1.</p> <p>OR</p> <p>The Responsible Entity identified the Elements for DDR as directed by Requirement R5, Part 5.1 or Part 5.4 but was late by greater than 60-calendar days and less than or equal to 90-calendar days.</p> <p>OR</p> <p>The Responsible Entity as directed by Requirement R5, Part 5.3 was late in notifying the owners by greater than 20-calendar days but less than or equal to 30-calendar days.</p>
Proposed Severe VSL	<p>The Responsible Entity identified the Elements for which DDR data is required as directed by Requirement R5 for less than or equal to 60% of the required Elements included in Part 5.1.</p> <p>OR</p>

VRF and VSL Justifications – PRC-002-2, R5	
	<p>The Responsible Entity identified the Elements for DDR as directed by Requirement R5, Part 5.1 or Part 5.4 but was late by greater than 90-calendar days.</p> <p>OR</p> <p>The Responsible Entity as directed by Requirement R5, Part 5.3 was late in notifying one or more owners by greater than 30-calendar days.</p> <p>OR</p> <p>The Responsible Entity failed to ensure a minimum DDR coverage per Part 5.2.</p>
<p>FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 2a: The VSL assignment is for R5 is not binary.</p> <p>Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R5	
<p>FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.</p>
<p>FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>	<p>Proposed VSLs are based on a single violation and not a cumulative violation methodology.</p>
<p>FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs</p>	<p>Non CIP</p>
<p>FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence</p>	<p>Non CIP</p>

VRF and VSL Justifications – PRC-002-2, R6	
Proposed VRF	Lower
NERC VRF Discussion	R6 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R6 provides criteria for Dynamic Disturbance Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes criteria for Dynamic Disturbance Recording selected in R5. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish criteria for Dynamic Disturbance Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R6 contains only one objective which is to establish criteria for Dynamic Disturbance Recording. Since the requirement has only one objective, only one VRF was assigned.

VRF and VSL Justifications – PRC-002-2, R6	
Proposed Lower VSL	The Transmission Owner had DDR data as directed by Requirement R6, Parts 6.1 through 6.4 that covered more than 75% but less than 100% of the total required electrical quantities for all applicable BES Elements.
Proposed Moderate VSL	The Transmission Owner had DDR data as directed by Requirement R6, Parts 6.1 through 6.4 for more than 50% but less than or equal to 75% of the total required electrical quantities for all applicable BES Elements.
Proposed High VSL	The Transmission Owner had DDR data as directed by Requirement R6, Parts 6.1 through 6.4 for more than 0% but less than or equal to 50% of the total required electrical quantities for all applicable BES Elements.
Proposed Severe VSL	The Transmission Owner failed to have DDR data as directed by Requirement R6, Parts 6.1 through 6.4.
<p>FERC VSL G1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p>	<p>Guideline 2a: The VSL assignment is for R8 is not binary.</p> <p>Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R6	
Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R7	
Proposed VRF	Lower
NERC VRF Discussion	R7 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R7 provides criteria for Dynamic Disturbance Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes criteria for Dynamic Disturbance Recording selected in R6. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish criteria for Dynamic Disturbance Recording could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R7 contains only one objective which is to establish criteria for Dynamic Disturbance Recording. Since the requirement has only one objective, only one VRF was assigned.

VRF and VSL Justifications – PRC-002-2, R7	
Proposed Lower VSL	The Generator Owner had DDR data as directed by Requirement R7, Parts 7.1 through 7.4 that covers more than 80% but less than 100% of the total required electrical quantities for all applicable BES Elements.
Proposed Moderate VSL	The Generator Owner had DDR data as directed by Requirement R7, Parts 7.1 through 7.4 for more than 70% but less than or equal to 80% of the total required electrical quantities for all applicable BES Elements.
Proposed High VSL	The Generator Owner had DDR data as directed by Requirement R7, Parts 7.1 through 7.4 for more than 60% but less than or equal to 70% of the total required electrical quantities for all applicable BES Elements.
Proposed Severe VSL	The Generator Owner failed to have DDR data as directed by Requirement R7, Parts 7.1 through 7.4.
<p>FERC VSL G1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.</p>
<p>FERC VSL G2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments</p>	<p>Guideline 2a: The VSL assignment is for R7 is not binary.</p> <p>Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R7	
that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R8	
Proposed VRF	Lower
NERC VRF Discussion	R8 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R8 provides criteria for Dynamic Disturbance Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement establishes the need for continuous data recording and storage for Dynamic Disturbance Recordings established in R6. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish continuous data recording and storage for Dynamic Disturbance Recordings established in R5 could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R8 contains only one objective to establish continuous data recording and storage for Dynamic Disturbance Recordings established in R6. Since the requirement has only one objective, only one VRF was assigned.

VRF and VSL Justifications – PRC-002-2, R8	
Proposed Lower VSL	The Transmission Owner or Generator Owner had continuous or non-continuous DDR data, as directed in Requirement R8, for more than 80% but less than 100% of the Elements they own as determined in Requirement R5.
Proposed Moderate VSL	The Transmission Owner or Generator Owner had continuous or non-continuous DDR data, as directed in Requirement R8, for more than 70% but less than or equal to 80% of the Elements they own as determined in Requirement R5.
Proposed High VSL	The Transmission Owner or Generator Owner had continuous or non-continuous DDR data, as directed in Requirement R8, for more than 6% but less than or equal to 70% of the Elements they own as determined in Requirement R5.
Proposed Severe VSL	The Transmission Owner or Generator Owner failed to have continuous or non-continuous DDR data, as directed in Requirement R8, for the Elements they own as determined in Requirement R5.
FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent	Guideline 2a: The VSL assignment is for R8 is not binary. Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.

VRF and VSL Justifications – PRC-002-2, R8	
Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R9	
Proposed VRF	Lower
NERC VRF Discussion	R9 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R9 provides criteria for Dynamic Disturbance Recordings which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement established technical specifications for Dynamic Disturbance Recording selected in R6. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to establish technical specifications for Dynamic Disturbance Recording selected in R6 could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R9 contains only one objective which is to establish technical specifications for Dynamic Disturbance Recording selected in R6. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner had DDR data that meets more than 80% but less than 100% of the total recording properties as specified in Requirement R9.

VRF and VSL Justifications – PRC-002-2, R9	
Proposed Moderate VSL	The Transmission Owner or Generator Owner had DDR data that meets more than 70% but less than or equal to 80% of the total recording properties as specified in Requirement R9.
Proposed High VSL	The Transmission Owner or Generator Owner had DDR data that meets more than 60% but less than or equal to 70% of the total recording properties as specified in Requirement R9.
Proposed Severe VSL	The Transmission Owner or Generator Owner had DDR data that meets less than or equal to 60% of the total recording properties as specified in Requirement R9.
FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 2a: The VSL assignment is for R9 is not binary. Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.
FERC VSL G3	Guideline 3- Consistency among Reliability Standards

VRF and VSL Justifications – PRC-002-2, R9	
Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	This requirement established technical specifications for Dynamic Disturbance Recording selected in R5. The team could not identify other continent-wide reliability standards of the same nature.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the ‘weakest link’ characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R10	
Proposed VRF	Lower
NERC VRF Discussion	R10 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R10 requires time synchronization of Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data which falls under Recommendation 12 of the Blackout Report and is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard This requirement does not have parts.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement calls for time synchronization for Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data for locations established in R1 and R5. The team could not identify other continent-wide reliability standards of the same nature.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failures to time synchronize Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R10 contains only one objective which is to time synchronize Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner had time synchronization per Requirement R10, Parts 10.1 and 10.2 for SER, FR, and DDR data for more than 90% but less than 100% of the bus

VRF and VSL Justifications – PRC-002-2, R10	
	locations as per Requirements R1 and Elements as per Requirement R5 as directed by Requirement R10.
Proposed Moderate VSL	The Transmission Owner or Generator Owner had time synchronization per Requirement R10, Parts 10.1 and 10.2 for SER, FR, and DDR data for more than 80% but less than or equal to 90% of the bus locations as per Requirements R1 and Elements as per Requirement R5 as directed by Requirement R10.
Proposed High VSL	The Transmission Owner or Generator Owner had time synchronization per Requirement R10, Parts 10.1 and 10.2 for SER, FR, and DDR data for more than 70% but less than or equal to 80% of the bus locations as per Requirements R1 and Elements as per Requirement R5 as directed by Requirement R10.
Proposed Severe VSL	The Transmission Owner or Generator Owner failed to have time synchronization per Requirement R10, Parts 10.1 and 10.2 for SER, FR, and DDR data for less than or equal to 70% of the bus locations as per Requirements R1 and Elements as per Requirement R5 as directed by Requirement R10.
FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	The proposed VSL's provide a broader compliance range than the associated VSL's in PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
FERC VSL G2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent	Guideline 2a: The VSL assignment is for R10 is not binary. Guideline 2b: The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.

VRF and VSL Justifications – PRC-002-2, R10	
Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R11	
Proposed VRF	Lower
NERC VRF Discussion	R11 is administrative in nature and a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R11 provides criteria around timelines for providing the data and the data format. This is consistent with FERC guideline G1.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard The requirement has parts that are of equal importance; only one VRF was assigned so there is no conflict.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement sets the criteria on providing Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data for locations selected in R1 and Elements established in R5.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to provide Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data for locations selected in R1 and Elements established in R5 could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R11 contains only one objective which is to provide Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data within the specified criteria. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner as directed by Requirement R11, Part 11.1 provided the requested data more than 30-

VRF and VSL Justifications – PRC-002-2, R11	
	<p>calendar days but less than 40-calendar days after the request unless an extension was granted by the requesting authority.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11 provided more than 90% but less than 100% of the requested data.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11, Parts 11.3 through 11.5 provided more than 90% but less than 100% in the proper data format.</p>
Proposed Moderate VSL	<p>The Transmission Owner or Generator Owner as directed by Requirement R11, Part 11.1 provided the requested data more than 40-calendar days but less than or equal to 50-calendar days after the request unless an extension was granted by the requesting authority.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11 provided more than 80% but less than or equal to 90% of the requested data.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11, Parts 11.3 through 11.5 provided more than 80% but less than or equal to 90% in the proper data format.</p>
Proposed High VSL	<p>The Transmission Owner or Generator Owner as directed by Requirement R11, Part 11.1 provided the requested data more than 50-calendar days but less than or equal to 60-calendar days after the request unless an extension was granted by the requesting authority.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11 provided more than 70% but less than or equal to 80% of the requested data.</p> <p>OR</p>

VRF and VSL Justifications – PRC-002-2, R11	
	The Transmission Owner or Generator Owner as directed by Requirement R11, Parts 11.3 through 11.5 provided more than 70% but less than or equal to 80% in the proper data format.
Proposed Severe VSL	<p>The Transmission Owner or Generator Owner as directed by Requirement R11, Part 11.1 failed to provide the requested data more than 60-calendar days after the request.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11 failed to provide less than or equal to 70% of the requested data.</p> <p>OR</p> <p>The Transmission Owner or Generator Owner as directed by Requirement R11, Parts 11.3 through 11.5 provided less than or equal to 70% in the proper data format.</p>
<p>FERC VSL G1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	The proposed VSL's provide a broader compliance range than the associated VSL's in PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
<p>FERC VSL G2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p>	<p>Guideline 2a:</p> <p>The VSL assignment is for R11 is not binary.</p> <p>Guideline 2b:</p> <p>The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>

VRF and VSL Justifications – PRC-002-2, R11	
Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	
FERC VSL G3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.
FERC VSL G4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations	Proposed VSLs are based on a single violation and not a cumulative violation methodology.
FERC VSL G5 Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs	Non CIP
FERC VSL G6 VSLs for cyber security requirements containing interdependent tasks of documentation and implementation should account for their interdependence	Non CIP

VRF and VSL Justifications – PRC-002-2, R12	
Proposed VRF	Lower
NERC VRF Discussion	R12 is a requirement in a long-term planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state of capability of the BES, or the ability to effectively monitor, control, or restore the BES.
FERC VRF G1 Discussion	Guideline 1- Consistency w/ Blackout Report R12 provides criteria around the availability of Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data.
FERC VRF G2 Discussion	Guideline 2- Consistency within a Reliability Standard This requirement does not have parts.
FERC VRF G3 Discussion	Guideline 3- Consistency among Reliability Standards This requirement sets the criteria around the availability of Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data.
FERC VRF G4 Discussion	Guideline 4- Consistency with NERC Definitions of VRFs Failure to follow the criteria around the availability of Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data could not directly affect the electrical state or capability of the BES, or the ability to effectively monitor and control the BES. Violation of the requirement will not lead to bulk electric system instability, separation, or cascading failures. The VRF for this requirement is “Lower” which is consistent with NERC guidelines for similar requirements.
FERC VRF G5 Discussion	Guideline 5- Treatment of Requirements that Co-mingle More than One Obligation R12 contains only one objective which is to establish criteria around the availability of Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording data. Since the requirement has only one objective, only one VRF was assigned.
Proposed Lower VSL	The Transmission Owner or Generator Owner as directed by Requirement R12 reported a failure and provided a Corrective Action

VRF and VSL Justifications – PRC-002-2, R12	
	Plan to the Regional Entity more than 90-calendar days but less than 100-calendar days after discovery of the failure.
Proposed Moderate VSL	The Transmission Owner or Generator Owner as directed by Requirement R12 reported a failure and provided a Corrective Action Plan to the Regional Entity more than 100-calendar days but less than or equal to 110-calendar days after discovery of the failure.
Proposed High VSL	The Transmission Owner or Generator Owner as directed by Requirement R12 reported a failure and provided a Corrective Action Plan to the Regional Entity more than 110-calendar days but less than or equal to 120-calendar days after discovery of the failure. OR The Transmission Owner or Generator Owner as directed by Requirement R12 submitted a CAP to the Regional Entity but failed to implement it.
Proposed Severe VSL	The Transmission Owner or Generator Owner as directed by Requirement R12 failed to report a failure and provide a Corrective Action Plan to the Regional Entity more than 120-calendar days after discovery of the failure. OR Transmission Owner or Generator Owner as directed by Requirement R12 failed to restore the recording capability and failed to submit a CAP to the Regional Entity.
FERC VSL G1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	PRC-002-2 differs from PRC-002-1 (not enforceable) and PRC-018-1 (enforceable and will be retired upon approval of PRC-002-2) in that PRC-002-2 deals with Sequence of Events Recording, Fault Recording, and Dynamic Disturbance Recording in order to adequately capture data for events analysis; and not equipment as referenced in the PRC-002-1 and PRC-018-1. Therefore, the VSL's cannot be compared between PRC-002-2 and PRC-018-1. The VSL's for this requirement meet or exceed the current level of compliance.
FERC VSL G2 Violation Severity Level Assignments Should Ensure	Guideline 2a: The VSL assignment is for R12 is not binary.

VRF and VSL Justifications – PRC-002-2, R12	
<p>Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 2b:</p> <p>The propose VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>
<p>FERC VSL G3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>The proposed VSL uses similar terminology to that used in the associated requirement, and is therefore consistent with the requirement.</p>
<p>FERC VSL G4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>	<p>Proposed VSLs are based on a single violation and not a cumulative violation methodology.</p>
<p>FERC VSL G5</p> <p>Requirements where a single lapse in protection can compromise computer network security, i.e., the 'weakest link' characteristic, should apply binary VSLs</p>	<p>Non CIP</p>
<p>FERC VSL G6</p> <p>VSLs for cyber security requirements containing interdependent tasks of documentation and</p>	<p>Non CIP</p>

Project VRF and VSL Justifications

VRF and VSL Justifications – PRC-002-2, R12

implementation should account for their interdependence	
---	--