

## Implementation Plan for Reliability Coordination Standards

---

### Implementation Plan Contents:

Prerequisite Approvals .....	2
Conforming Changes to Requirements in Already Approved Standards.....	2
Revisions or Retirements to Already Approved Standards .....	3
Effective Dates .....	5

### **Prerequisite Approvals**

- None required

### **Conforming Changes to Requirements in Already Approved Standards**

- IRO-014-2

### **Revision Summary**

The RCSDT recommends retiring Standard IRO-015 and moving all requirements to IRO-014-2.

**Revisions or Retirements to Already Approved Standards**

The following tables identify the sections of approved standards that shall be retired or revised when this standard is implemented. If the drafting team is recommending the retirement or revision of a requirement, that text is blue.

<b>Already Approved Standard</b>	<b>Proposed Replacement Requirement(s)</b>
----------------------------------	--

**Implementation Plan for Reliability Coordination Standards**

<p><b>IRO-015-1</b></p> <p><b>R1.</b> The Reliability Coordinator shall follow its Operating Procedures, Processes, or Plans for making notifications and exchanging reliability-related information with other Reliability Coordinators. <i>[Violation Risk Factor: Medium]</i></p> <p><b>R1.1.</b> The Reliability Coordinator shall make notifications to other Reliability Coordinators of conditions in its Reliability Coordinator Area that may impact other Reliability Coordinator Areas. <i>[Violation Risk Factor: Medium]</i></p> <p><b>R2.</b> The Reliability Coordinator shall participate in agreed upon conference calls and other communication forums with adjacent Reliability Coordinators. <i>[Violation Risk Factor: Lower]</i></p> <p><b>R2.1.</b> The frequency of these conference calls shall be agreed upon by all involved Reliability Coordinators and shall be at least weekly. <i>[Violation Risk Factor: Lower]</i></p> <p><b>R3.</b> The Reliability Coordinator shall provide reliability-related information as requested by other Reliability Coordinators. <i>[Violation Risk Factor: Medium]</i></p> <div data-bbox="251 1575 727 1705" style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p><i>The RCSDT proposes retiring R3 (as shown above) as it is redundant with proposed R5 in the right column.</i></p> </div>	<p>The RCSDT recommends retiring Standard IRO-015 and moving all requirements to IRO-014-2 and revising as shown. Proposed IRO-014-2, R5-6:</p> <p><b>R5.</b> The Reliability Coordinator shall make notifications and exchange reliability-related information with impacted Reliability Coordinators using its predefined <del>shall follow its Operating Procedures, Processes, or Plans for conditions that may impact other Reliability Coordinator Areas or other means to accomplish the notifications and exchange of reliability-related information.</del> <del>for making notifications and exchanging reliability-related information with impacted other Reliability Coordinators.</del> <i>[Violation Risk Factor: Medium][Time Horizon: Real-time Operations and Operations Planning]</i></p> <p><del>R5.1 The Reliability Coordinator shall make notifications to impacted other Reliability Coordinators of conditions in its Reliability Coordinator Area that may impact other Reliability Coordinator Areas. <i>[Violation Risk Factor: Medium]</i></del></p> <p><b>R6.</b> The Reliability Coordinator shall participate in agreed upon conference calls and other communication forums with <del>impacted adjacent</del> Reliability Coordinators. <i>[Violation Risk Factor: Lower][Time Horizon: Real-time Operations]</i></p> <p>R6.1 The frequency of these conference calls shall be agreed upon by all involved Reliability Coordinators and shall be at least weekly. <del><i>[Violation Risk Factor: Lower]</i></del></p> <p><del>R7. The Reliability Coordinator shall provide reliability-related information as requested by other Reliability Coordinators. <i>[Violation Risk Factor: Medium]</i></del></p> <div data-bbox="1036 1417 1459 1516" style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p><i>The RCSDT proposes retiring R7 as it is redundant with R5.</i></p> </div>
<p><b>Notes:</b></p>	

**Implementation Plan for Reliability Coordination Standards**

---

Functions that Must Comply with the Requirements in the Standards

Standard	Functions that Must Comply With the Requirements						
	Reliability Coordinator	Balancing Authority	Interchange Authority	Transmission Operator	Transmission Owner	Generator Owner	Generator Operator
IRO-015	X						

**Effective Dates**

TBD