

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Special Report

Flexibility Requirements and Potential Metrics for Variable Generation: Implications for System Planning Studies

August 2010


to ensure
the reliability of the
bulk power system

116-390 Village Blvd., Princeton, NJ 08540
609.452.8060 | 609.452.9550 fax
www.nerc.com

NERC's Mission

The North American Electric Reliability Corporation (NERC) is an international regulatory authority established to evaluate reliability of the bulk power system in North America. NERC develops and enforces Reliability Standards; assesses adequacy annually via a 10-year forecast and winter and summer forecasts; monitors the bulk power system; and educates, trains, and certifies industry personnel. NERC is the electric reliability organization for North America, subject to oversight by the U.S. Federal Energy Regulatory Commission (FERC) and governmental authorities in Canada.¹

NERC assesses and reports on the reliability and adequacy of the North American bulk power system, which is divided into eight Regional areas as shown on the map below and listed in Table A. The users, owners, and operators of the bulk power system within these areas account for virtually all the electricity supplied in the U.S., Canada, and a portion of Baja California Norte, México.



Note: The highlighted area between SPP and SERC denotes overlapping regional area boundaries. For example, some load serving entities participate in one region and their associated transmission owner/operators in another.

Table A: NERC Regional Entities

FRCC Florida Reliability Coordinating Council	SERC SERC Reliability Corporation
MRO Midwest Reliability Organization	SPP Southwest Power Pool, Incorporated
NPCC Northeast Power Coordinating Council	TRE Texas Reliability Entity
RFC ReliabilityFirst Corporation	WECC Western Electricity Coordinating Council

¹ As of June 18, 2007, the U.S. Federal Energy Regulatory Commission (FERC) granted NERC the legal authority to enforce Reliability Standards with all U.S. users, owners, and operators of the BPS, and made compliance with those standards mandatory and enforceable. In Canada, NERC presently has memorandums of understanding in place with provincial authorities in Ontario, New Brunswick, Nova Scotia, Québec, and Saskatchewan, and with the Canadian National Energy Board. NERC standards are mandatory and enforceable in Ontario and New Brunswick as a matter of provincial law. NERC has an agreement with Manitoba Hydro making reliability standards mandatory for that entity, and Manitoba has recently adopted legislation setting out a framework for standards to become mandatory for users, owners, and operators in the province. In addition, NERC has been designated as the “electric reliability organization” under Alberta’s Transportation Regulation, and certain reliability standards have been approved in that jurisdiction; others are pending. NERC and NPCC have been recognized as standards-setting bodies by the *Régie de l’énergie* of Québec, and Québec has the framework in place for reliability standards to become mandatory. Nova Scotia and British Columbia also have frameworks in place for reliability standards to become mandatory and enforceable. NERC is working with the other governmental authorities in Canada to achieve equivalent recognition.

Table of Contents

NERC’s Mission	i
Chapter 1: Introduction	1
Chapter 2: System Flexibility Requirements	3
2.1 Introduction.....	3
2.2 The Importance of Net Load.....	3
2.3 Lessons Already Learned.....	5
2.3.1 Bonneville Power Administration (BPA).....	6
2.3.2 Electric Reliability Council of Texas (ERCOT)	7
2.3.3 New York Independent System Operator (NYISO).....	11
Chapter 3: Sources of Increased System Flexibility	14
3.1 Introduction - Sources of Increased System Flexibility.....	14
3.2 Flexible Conventional Generation	14
3.3 Demand Response.....	15
3.4 Variable Generation Power Management (Curtailment)	15
3.5 Energy Storage.....	16
3.6 Electric Vehicles	16
3.7 Sub-Hourly Generation Scheduling.....	17
3.8 Consolidation of Balancing Areas	17
3.9 Enabling Flexibility through Transmission Planning	18
3.10 Institutional Aspects of Natural Gas Transportation	18
3.11 Conclusion	19
Chapter 4: Measuring Flexibility	20
4.1 Introduction.....	20
4.2 Characteristics of Demand and Supply Imbalances and Need for System Flexibility	20
4.3 Impact of Variable Generation on Imbalance and Net Load Ramping Characteristics...	21
4.4 Characteristics of Flexible Resources	21
4.5 Metrics for Load Ramping, Supply and Demand Imbalances and Flexible Resources...	22
4.6 Flexibility Resource Scheduling.....	24
4.7 Summary - Measuring Flexibility.....	25
Chapter 5: Conclusions and Recommendations	26
Appendix: Examples of Variable Generation Integration	29
Introduction.....	29
BPA Example.....	29
AESO Example.....	31
ERCOT Example	34
Midwest Independent System Operator Example.....	42

New York Independent System Operator Example.....	47
European Examples	51
IVGTF Task Force 1-4 Roster	56

Chapter 1: Introduction

In April 2009, the NERC Integration of Variable Generation Task Force (IVGTF) released its landmark special report entitled: “*Accommodating High Levels of Variable Generation.*”² One of the primary findings of that report is that as the penetration of variable generation reaches relatively high levels, the characteristics and operation of the bulk power system will be significantly altered. The primary driver of this change is the increase in the overall system variability.

The IVGTF Report resulted in a number of conclusions and recommended actions to develop the planning and operational practices as well as the methods and resources needed to integrate variable generation resources into the bulk power system. The focus of this work effort is on Task 1.4 of the IVGTF Report which was defined as follows (see box to the right): “*Resource adequacy and transmission planning approaches must consider needed system flexibility to accommodate the characteristics of variable resources as part of bulk power system design.*”

This report documents the extent to which resource adequacy and transmission planning processes may certainly need to consider system flexibility to accommodate the characteristics of variable resources as part of bulk power system design. Planning studies have historically concentrated on the concept of adequacy. In 1996, Billinton & Allan³ suggested that system security, a subset of which is defined here as system flexibility, was “*an exciting area for future development and research.*” Task Force 1.4 has developed a study approach that will; 1) Describe the characteristics of the net load to be served by conventional generation and the need for flexibility; 2) Document the experience of power systems that already have a relatively high penetration of variable generation; 3) Identify sources of flexibility; 4) Discuss metrics that can be used to characterize flexibility; 5) Discuss the tools required for system planning to include system flexibility and to present conclusions and recommendations. This information will be used to determine how

The focus of this report addresses Task 1.4 of the IVGTF Report work plan:

Resource adequacy and transmission planning approaches must consider needed system flexibility to accommodate the characteristics of variable resources as part of bulk power system design. The NERC Planning Committee’s Resource Issues Subcommittee should study changes required to current resource adequacy assessment processes to account for large-scale variable generation integration. Considerations should include ramping requirements, minimum generation levels, required shorter scheduling intervals, transmission interconnections, etc.”

This task report concentrates on how to assimilate or consider variable generation into resource and transmission planning. Data needs will be identified and the report is to make recommendations responsible NERC entities. The goals of the report are to

- *Study resource and transmission planning process changes required to include variable generation characteristics.*
- *Identify data requirements to support resource adequacy assessment and, which NERC entities should collect, retain and provide this data.*

² 2009 *Accommodating High Levels of Variable Generation* http://www.nerc.com/files/IVGTF_Report_041609.pdf

³ Billinton, R. and Allan, R., 1996, *Reliability Evaluation of Power Systems*, Plenum, New York.

flexibility could be accounted and measured in existing studies, whether flexibility should be accounted for differently in planning studies and what kind of metrics could be needed to measure flexibility.

Historically, system planning studies generally have and had not explicitly addressed the need for system flexibility, since as the characteristics and performance of conventional generating technologies included design requirements to meet variable and randomness from demand, which is well understood and predictable. Power system variability was addressed in resource planning studies by identifying the most economic resource mix to meet a time varying load profile, and in transmission planning studies by evaluating loss of source in the local area. However, for reliable operation, adequate amounts of system flexibility are required to accommodate large amounts of variable generation. Without this flexibility, the penetration of variable generations may be limited in order to ensure the reliability of the bulk power system. Therefore, planning and design processes will need to change, depending on basic system characteristics, to provide the flexibility needed to meet targeted levels of variable generation. Developments of appropriate flexibility metrics is an important aspect in facilitating these new processes.

This report documents how variable generation will increase the need for the power system to be able respond to increased variability, how power systems have begun to address the need for increased flexibility, sets forth a framework to measure flexibility and concludes with how recent large-scale variable generation integration studies provide a framework for addressing flexibility in planning studies. Finally, the report presents recommendations as to how a set of best practices can be developed for modifying planning tools now to address flexibility, and how the state-of-the-art for conducting system planning studies can be advanced to more effectively capture the need for increased flexibility. Charting new ground is always challenging. The development of metrics for a multi-dimensional concept, such as power system flexibility and incorporating it into planning studies presents a significant challenge. This report provides a framework to accomplish that end and a foundation for future work.

Chapter 2: System Flexibility Requirements

2.1 Introduction

Chapter 2 of the IVGTF Special Report entitled: “*Accommodating High Levels of Variable Generation*”⁴ identified the characteristics of variable generation and how they can result in a system that will be inherently more variable, which will require more system flexibility. Historically, power systems have been designed to deal with variability. This variability is primarily driven by the load cycle, short-term random load fluctuations and sudden loss of facilities and/or sources of supply. The introduction of variable generation can result in increased overall variability requiring response from the bulk power system. This variability must be quantified to address the need for system flexibility.

2.2 The Importance of Net Load

Net load to be served by the bulk power system is the aggregate of customer demand reduced by variable generation power output. Flexible resources must be adjusted to maintain a balance with net load. Some of the dispatchable resources may alter net load such as conventional customer generation, controllable Demand Response and variable generation curtailment.

For modeling changes in power system variability resulting from the addition of variable generation to the resource mix, variable generation output is best combined with load to create net load. The reason for this summation is variable generation output and system electric demand have similar characteristics.

“The Concept of Net Load”

The concept of net load (demand minus variable generation) or more specifically the change in net load or the net-load delta is used in this document as a metric for evaluating the need for additional flexibility that results from higher levels of installed variable generation. The demand component of the net load calculation should be consistent with the NERC definitions of demand as follows:

Total Internal Demand: Is the sum of the metered (net) outputs of all generators within the system and the metered line flows into the system, less the metered line flows out of the system. The demands for station service or auxiliary needs (such as fan motors, pump motors, and other equipment essential to the operation of the generating units) are not included. Internal Demand includes adjustments for all non-dispatchable Demand Response programs (such as Time-of-Use, Critical Peak Pricing, Real Time Pricing and System Peak Response Transmission Tariffs) and some dispatchable Demand Response (such as Demand Bidding and Buy-Back).

Net Internal Demand: Equals the Total Internal Demand reduced by the total Dispatchable, Controllable, Capacity Demand Response equaling the sum of Direct Control Load Management, Contractually Interruptible (Curtable), Critical Peak Pricing (CPP) with

⁴ http://www.nerc.com/files/IVGTF_Report_041609.pdf

Variable generation is:

- Cyclic on an annual (seasonal) basis, with some diurnal (daily) patterns but not as strong as the load
- Subject to random short-term variations around a forecasted multi-hour trend
- Limited controllability (i.e. ability to dispatch)
- Subject to deviations from predicted day-ahead behavior, with larger forecast error than load.
- Dependent on prevailing weather conditions
- Demand and variable generation can be correlated. Namely, weather patterns can impact their character.


Determining the impacts of variable generation on bulk power system operations and planning should be evaluated by examining variable generation output characteristics simultaneously with the behavior of the load. For example, analysis of variable generation must include load variation to determine the need for flexibility. From a modeling perspective, the net load has larger forecast errors than the load in isolation.

Change in load and variable generation can reduce or increase the net load. In other words, given synchronized load and variable generation time series, the variability of net load over a time period is less than the sum of the variability of the individual series over the same time period. In addition, the variability of each cannot simply be combined as if they are independently random, as they may both be affected by the common factor of the weather.

The impact of variable generation on system variability can be demonstrated by comparing the distribution of load changes to the distribution of *net* load changes, (include both the effects of variable generation and the load changes) for any specified time frame. Figure 2-1 below displays the difference of the load and net changes for sixty-minute intervals. The graphic is based on installed nameplate wind, which totals 8,000 MW, and a peak load of approximately 37,000 MW.

When net load is included, it is considerably more variable than the load by itself and increases as the amount of variable generation increases. This results in a need for greater system flexibility. Although the timeframe is one hour, in general, the distribution is similar for other timeframes, validated in many other studies of wind integration.

Figure 2-1: Distribution of One-Hour Load Changes and One-Hour Net Load Changes⁵



2.3 Lessons Already Learned


Many power systems in the United States and in Europe have gained considerable understanding of the need for flexibility. Experiences of power system with variable generation integration have been compiled from examples throughout the world. The full description of each of the systems that submitted their experiences are in the Appendix, entitled, *Examples of Variable Generation Integration*. The Appendix and this report are dominated by wind examples, with some reference to solar and ocean energy. Solar energy is growing rapidly but thus far there are no known significant impacts (in North America or elsewhere) that would highlight the need for flexibility. Ocean energy is in its infancy but may in the future have significant impact. Below is a summary of three systems, from three of the four major interconnections in North America and a summary of the lessons-learned to date from integrating wind.

⁵ Based on 2006 wind data and developed from the data developed by AWS Truewind for the Eastern Wind Integration and Transmission Study (EWITS).

2.3.1 Bonneville Power Administration (BPA)

As of November 2009, BPA had 2,253 MW of installed wind capacity connected within its balancing authority (BA). With a peak net internal demand of 10,500 MW, wind penetration in the BPA BA is over 20 percent of peak demand. Figure 2-2 is an example of the variability of wind generation in the month of February 2009. This variability is managed by provision of ancillary services from conventional dispatchable generators. For example, in the BPA BA, flexible resources are required to supply regulating and following reserves.

Figure 2-2: BPA Wind Generation



BPA began tabulating ramp rates for 5-minute, 30-minute and 60-minute increments to measure flexibility requirements. The following are the maximum ramps experienced on an installed wind capacity basis:

1. **5-Minute Increment:** 21.0 percent of capacity up and 48.4 percent of capacity down
2. **30-Minute Increment:** 50.8 percent of capacity up and 49.4 percent of capacity down
3. **60-Minute Increment:** 66.7 percent of capacity up and 48.8 percent of capacity down

The amount of flexible resources needed is shaped by the magnitude of these ramps in any wind regime. However, if wind generation output forecasting methods are not accurate enough to provide sufficient notice to the operator, a more robust flexible system is needed to address

both the forecast uncertainty and ramps. Therefore, it is vital that experience with and the accuracy of wind output forecasting continue to improve to support effective planning and operations.

The primary lessons drawn from the BPA experience include the importance of:


1. Wind generation output forecasting accuracy⁶
2. Operational controls, i.e. the ability of the BA to feather wind and/or curtail schedules if reserve levels are close to being exceeded
3. Scheduling intervals supporting firm wind generation export requirements.

2.3.2 Electric Reliability Council of Texas (ERCOT)

As of January 2010, ERCOT had 8,916 MW of installed wind capacity on its system. In ERCOT, wind penetration has been significant and represented up to as much as 25 percent of the load. For example, at 3am on 10/28/2009, ERCOT load reached 22,893 MW while the wind generation produced 5,667 MW, in comparison to the all-time wind generation peak output of 6,223 MW on the same day.

As shown (Figure 2-3a), ERCOT has experienced one hour ramps increasing by 3,039 MW and a decreasing by 2,847 MW. This illustrates the short-term variability in wind generator output that can be managed by either dynamically controlling variable generation and load, or the use of other flexible, dispatchable resources.


Figure 2-3a: Wind Increase (18-Apr-09 23:39 to 19-Apr-09 00:39) and Wind Decrease (10-Jun-09 16:35 to 10-Jun-09 17:35).



⁶ Variable Generation Power Forecasting for Operations [http://www.nerc.com/docs/pc/ivgtf/Task2-1\(5.20\).pdf](http://www.nerc.com/docs/pc/ivgtf/Task2-1(5.20).pdf)

In ERCOT, the updated resource plan for wind captured one hour prior to the beginning of an operating hour is then incorporated into ERCOT’s look-ahead planning tools (Figure 2-3b). In this example, the forecast showed large wind energy availability. However, unexpectedly, there was a steady decline in energy available in the Balancing Energy stack, combined with the depletion of up-regulation service between 18:00 and the declaration of Emergency Electric Curtailment Plan (EECP) at 18:41. ERCOT’s forecast tools did not detect the approaching problem due to inaccurate input data from the resource plans.

Figure 2-3b: One hour prior to the beginning of an operating hour is incorporated into ERCOT’s look-ahead planning tools



Note the large negative Schedule Control Error (SCE) in wind-only Qualified Scheduling Entities (QSE) and lesser negative SCE of non-wind QSE’s around 18:30.⁷ Responsive reserve deployment at 18:33 briefly assisted in supporting frequency, but the system failed to restore to 60 Hertz.

⁷ SCE performance after deployment of Responsive Reserve, as shown in green, should not be considered because responsive reserve deployments are not expected to honor QSE’s ramp rates

As shown in Figure 2-3c, the Day Ahead Replacement Reserve (RPRS) market study for the Operating Day of February 26, 2008 procured no units for congestion and capacity for the evening hours. The total hourly average on-line capacity at the hour ending at 19:00 in the RPRS market study was 38,693 MW; the actual hourly average on-line system capacity in real-time was 38,062 MW, less than the day-ahead resource plan capacity by 631 MW. There was an additional unscheduled 600 MW of energy exported across the DC Tie. At 19:00 in the Day-ahead Resource Plan (Figure 2-4a), wind generation was scheduled to generate 1,294 MW; real-time wind generation was approximately 335 MW, when Emergency Electric Curtailment Plan (EECP) was declared (Table 2-1).

**Figure 2-3c: Regulation, Remaining Balancing in Bid Stack, and Frequency for 02/26/08
18:00 – 19:30**




Figure 2-4a: 1-HOUR-AVERAGE REAL-TIME ONLINE CAPACITY AND 1-HOUR-AVERAGE DAY-AHEAD ONLINE CAPACITY 02/26/08 16:00 – 20:00





Table 2-1: Day-Ahead Replacement Reserves for the Operating Day of February 26th, 2008

	1-HR AVG Real-Time Online Capacity	1-HR AVG Day-Ahead Online Capacity
16:00	37,885	38,923
17:00	37,746	38,249
18:00	37,514	38,924
19:00	38,062	38,693
20:00	40,237	38,864

As shown in Figure 2-4b, the deployment of Load Acting as a Resource (LaaRs) was deployed to operations, with only two participants failing to deploy within 10 minutes. The deployment of LaaRs appears to have halted the frequency decline and restored ERCOT to stable operation.

**Figure 2-4b: Load Acting as a Resources (LaaRs) Responsive Reserve (RRS)
DEPLOYMENT 02/26/08 18:30 – 19:30**



The primary lessons drawn from ERCOT's experience are the importance of:


1. Wind generation forecasting accuracy on a nodal basis
2. Procuring and scheduling sufficient resources to provide the needed flexibility
3. Load as a flexible resource

2.3.3 New York Independent System Operator (NYISO)

NYISO is the system operator for the New York Balancing Area, which encompasses the entire State of New York. Installed nameplate wind generation is now over 1,200 MW. The NYISO has experienced and analyzed rare events. For example, high speed cutout was experienced, resulting from wind conditions that exceed the capability of the wind turbines requiring them to shut down rapidly to protect the equipment. In addition, quick up-ramps were experienced as the wind speed picked up suddenly. Figure 5a&b below is an example of a high-speed cutout event observed on June 10, 2008. Illustrated in the five-minute time steps, a front containing thunderstorms moved from east to west across the Northern portion of the New York Control Area affecting wind plants at different locations on the system.

As the first set of plants (red line in Figure 5a) to encounter the front, the plants ramp up preceding the cutouts from 26 percent of nameplate to 61 percent of nameplate over 30 minutes and then ramp down from cutouts to 5 percent of nameplate over 10 minutes. After the storm passes, the plants ramped up to 82 percent of nameplate over 45 minutes. A similar pattern is observed later for the plants further to the east (green line). These changes in output were addressed within the NYISO's market-based Security Constrained Economic Dispatch (SCED) systems, which includes a scheduling/dispatch update every five minutes.

Figure 2-5a: High Speed Cut-out Event approx. 12 noon on 6/10/08. (The red line is wind plants in Northwest Central NY and green line are wind plants in Northeastern NY)




Energy market based solutions can reduce the effect of variability by curtailing output of variable resources. NYISO has observed the ability of wind plants to adjust the level of their output rapidly in response to changing system conditions, which can result in price changes. For example, Figure 5b shows the plants response to price signals on May 15, 2007. The five-minute prices at the generator bus or interconnection point of one of New York’s wind plants spiked as low as -\$4,000 per MWh. The plant reduced its output from 80 percent of nameplate to almost zero in a little over two minutes. This cleared the congestion problem. However, the plant only needed to move to about 60 percent of nameplate to clear the congestion, as the wind plant was not being supplied information about the appropriate generation level needed to clear congestion.

The primary lessons that can be drawn from the NYISO experience are as follows:

1. The importance of situational awareness because weather conditions alter the output of variable generation significantly over short periods of time.
2. The importance of market signals.
3. The importance of being able to send wind plant operators dispatch or base point signals.
4. The importance of interconnection requirements which requires wind plants to supply a full set of data for the supervisory control and data acquisition systems including meteorological data for the wind plant site.

Figure 5b: Wind Plant Response to Negative Prices



Chapter 3: Sources of Increased System Flexibility

3.1 Introduction - Sources of Increased System Flexibility

In many instances, designing systems to accommodate large penetration levels of variable generation will introduce the need to develop sources of flexibility needed to maintain reliability and improve operational efficiency. Although system operators can attempt to derive sufficient system flexibility from existing conventional resources, the physical constraints of the existing resource portfolio and/or the resulting cost may be challenging. Therefore, a broader mix of resources with flexible characteristics including storage technologies along with sufficient transmission may be needed by operators to manage the higher levels of variability and uncertainty. In addition, institutional and/or structural changes to markets and system operations can be undertaken to facilitate the power system's ability to respond to increased variability through more flexible use of existing resources. As an example, in the presence of a large instantaneous penetration of wind resources, the differences between actual generator demand for gas supply on the pipeline system and the anticipated day-ahead nomination schedule may become divergent, potentially stressing the gas supply and transportation system. This could potentially affect the flexibility of generation whose sole source of fuel is natural gas.

Increased flexibility can come from a number of potential sources such as the adoption of more flexible supply and demand-side technologies and/or through structural change. Reliability considerations and issues resulting from the need for this increased flexibility are briefly described in the following sections.

3.2 Flexible Conventional Generation

Flexibility can come from conventional generation designed to have more flexible characteristics, including:

1. Ramp rate
2. Operating range, including minimum generating level
3. Start-up/shut-down times
4. Minimum up and down times

Manufacturers are already developing units that have higher ramp rates and cycling capabilities, while managing the potential maintenance costs that result from this cycling. A more flexible conventional fleet will also require traditional base load units, such as coal and nuclear plants, which have lower minimum operating levels and increased ability to cycle. In a power market environment, these services are typically procured through day-ahead and hour-ahead markets. In a vertically integrated system, the different categories of ancillary services are procured by the utility as part of the inclusive service.

In power market environments, operational flexibility is of high value to system operators, while it has correspondingly little value for power suppliers, and therefore suppliers should be compensated for its provision. Understandably, generator owners and operators are reluctant to operate their generation at lower minimum turndowns, or to ramp up and down more frequently, as such actions imposes increased wear and tear on their units and direct costs such as increased fuel consumption and ability to meet environmental regulations. Thus, accessing greater flexibility from existing generation units will require market and/or policy changes. If market participants are provided incentives to do so, expanded flexibility will result in resource development that is offered to the market, and this approach can be used in preparation for increased variable generation resources. For example, price signals could be used to signal a greater need for load-following or multi-directional regulation services via an ancillary service markets. On the other hand, states or utilities with integrated resource planning processes could incorporate resource flexibility as a criterion for resource evaluation and implementation.

3.3 Demand Response

Demand Response or load management is defined as the ability of end users of electricity to reduce load in response to price signals or other grid management incentives and rules. Effective Demand Response programs can provide essential flexibility over relatively short timeframes when an unpredictable change in variable generation output occurs. Demand Response has already been shown in some BAs to be a flexible tool for operators to use with wind generation. Traditionally, Demand Response programs have been used to reduce peak electricity demand or providing planning reserve margins, rather than for operating reserves.

More recently, however, several BAs have realized the potential for controllable and dispatchable load programs to be used as a non-spinning or supplemental operating reserve. Demand Response, which is available as non-spinning or supplemental reserves can be used to respond to the sudden unexpected loss of a large resource or the unexpected loss of a large amount of variable generation over a short period of time. For example, the aforementioned ERCOT's ability to call on 1,200 MW of Demand Response to restore system frequency during the incident in Texas in February 2008, demonstrated the effectiveness of using Demand Response to enhance system flexibility (see Chapter 2 and detailed description in the Appendix: *Examples of Variable Generation Integration*). Alternatively, a load management program such as time-of-use rates that shifts load to off-peak periods when wind production is usually at its highest could be used to avoid curtailment of variable generation or minimize cycling of large base load power plants.

3.4 Variable Generation Power Management (Curtailment)

To the extent that energy markets and available operating reserves are insufficient to maintain reliability, out of market actions, including limiting or curtailing supply may be required to restore reliable system operation. Curtailment of variable generation output may be necessary if the amount available at a specific time is more than what the grid can reliably deliver while maintaining reliability. In fact, for power systems with small balancing areas dominated by thermal generation that are less flexible, wind curtailments could occur even at low variable generation penetrations. Recent wind integration studies and operating experience demonstrate

that at higher levels of penetration, wind generation may need to be curtailed during certain periods, unless suitable flexibility is designed into the bulk power system. Wind can also be curtailed to provide reserves i.e. a source of flexibility. The Bonneville Power Administration and the Alberta Electric Service Operator have each implemented operational procedures to curtail and or limit the ramping of variable generation on their systems under specified reliability-based criteria. These are discussed further in the Appendix. Typically, variable generation curtailment is required at generation surplus conditions, namely, low load with thermal unit dispatched at the minimum stable operating limits. Curtailment is also required under unforeseen (i.e. not forecasted) wind conditions such as wind gusts or microbursts, and under islanding conditions or system emergencies where wind variability cannot be tolerated.

3.5 Energy Storage

Energy storage technologies also have the potential to assist the large-scale integration of variable generation. The ability of storage to transform energy into capacity has many advantages depending on the technical capabilities and technology resource. Pumped hydro comprises the vast majority of energy storage used today, though there are numerous storage technologies in various stages of development and commercialization that can provide some level of system flexibility. Technologies, like battery energy storage (BESS), flywheel energy storage (FESS), and Compressed Air Energy Storage (CAES), continue to mature. Storage can be used to provide three varying support services:

1. **Load shifting service:** The storage system charges in periods of surplus and discharges during periods of scarcity
2. **Shorter-term balancing service:** Stored electricity is used to smooth variation of wind net load output thereby reducing the need for some spinning reserves
3. **Quick-acting instantaneous service:** The storage systems provide immediate frequency and regulation products.

The present economic drivers for energy storage with fast discharge are stronger than those with long-term discharge characteristics. However, the cost of storage devices compared to other methods of flexibility currently has limited their applicability to specific and limited situations. The benefits of energy storage are most broadly realized and valuable when operated as a system resource for the benefit of the entire system, and not in a dedicated mode for any individual resource such as variable wind plants. As a system resource, energy storage may be linked to power system network controls and responsive to system operators to provide ancillary services such as regulation, demand following (ramping), capacity, etc. As a network resource, it is available to balance variability of any combination of resources and demands.

3.6 Electric Vehicles

Electric vehicles (EVs), including Plug-in Hybrid Electric Vehicles (PHEV), may prove to be a source of flexibility for the electric power system sometime in the future. Use of plug-in all-electric and hybrid vehicles for storage of electricity is another variation of battery storage. As electric vehicles become available, they could also provide energy storage services that can benefit a bulk power system experiencing increasing levels of variability. The vision is when plugged in for charging, EVs and PHEVs could provide supplemental reserves as a Demand

Response type product or regulating reserve services. Many design hurdles need to be overcome, however, to fully capture the potential benefits of synergies between variable generation and electric vehicles. Further work on storage and electric vehicles is being carried out as part of IVGTF Task 1.5 activities.⁸

3.7 Sub-Hourly Generation Scheduling

In many BAs, generation is scheduled on an hourly basis with most generators following flat hourly schedules set one hour or more in advance. Changes in load or generation occurring within the hour, must be met by generating units providing regulation and load following services. Scheduling generation on shorter time intervals can reduce the need for units to provide costly regulation services, freeing them up to support system flexibility requirements. Sub-hourly energy markets can provide economic incentives for generators to respond when needed, improving ramping capability and reducing the need to dispatch generators out of economic merit order. Additionally, the sub-hourly scheduling reduces the period of uncertainty around wind generation schedules and allows wind plant owners to adjust schedules more frequently. For example, with these potential benefits in mind, BPA has recently announced plans to start a sub-hourly scheduling pilot to allow wind generators to purchase and sell on a half-hourly basis. Based on the pilot results, all generators may participate in this program.⁹

3.8 Consolidation of Balancing Areas

NERC currently lists 131 balancing areas (BAs) within North America. As the term implies, each BA must continuously balance load and generation within its area. If there is sufficient transmission capacity, increasing the size of a BA or collectively sharing the balancing obligation among a group of balancing areas can provide more flexibility to integrate variable generation in at least two respects. First, larger BAs provide access to more available generating resources and other sources of flexibility. Second, a larger BA can take advantage of the geographic diversity of wind resources across a larger footprint, thereby helping to smooth the variability of wind production. Recent studies show that balancing area consolidation will reduce the ramping requirements for load, wind, and load with wind. Results reveal that the ramping penalty associated with operating independent balancing areas increases significantly when there is significant wind penetration.

The ACE Diversity Interchange (ADI) pilot project underway among utilities in the Western Electric Coordinating Council (WECC) is an example of BAs sharing balancing responsibilities without actually consolidating BAs. Unlike conventional consolidation, this approach will not interchange power between Balancing Areas. Rather, the objective is to minimize regulation among a group BAs by executing contracts that obligates the participants to pool regulation resources. The ADI project pools ACE signals from thirteen BAs within WECC, and sends AGC (automatic generation control) signals based on the reduced requirement that is based on the combined requirements for system balance. By sharing ACE among multiple control areas, the diversity in load and generating resources is captured. Early

⁸ See Page 70 of http://www.nerc.com/files/IVGTF_Report_041609.pdf

⁹ http://www.bpa.gov/corporate/windpower/docs/WIT_Work_Plan_-_June_16.pdf

experience with ADI indicated improvements in meeting ACE requirements and in other reliability performance measures.

3.9 Enabling Flexibility through Transmission Planning

Transmission (internal within a system and to other systems) by itself does not provide flexibility. However, transmission provides access to additional sources of needed flexible resources creating a vehicle to share them between BAs.

Because much of the variability in variable generation resources is due to the presence, or absence, of the ‘fuel’ source at a specific physical location, inclusion of a larger number of diverse locations of variable generation would reduce the overall change in the supply and demand balances for a specific ramping event. In order to include a wider array of sources, it is necessary to ensure adequate transmission between those diverse areas.

In recognition of variable resource output, transmission planning studies need to include the likelihood that there will be no wind and that the transmission network must be able to operate under these conditions. This requires not only design-focused planning studies to consider this eventuality, but near-term operating studies as well. These operating studies may include unit commitment studies as well as maintenance planning for both resource and transmission maintenance activities. Unit commitment studies should consider the possibility of wind not being available as well as the possibility of higher than anticipated wind generations. The ability of flexible resources to respond to dispatch signals and prevailing spot prices may affect a daily operating plan.

While the loss of generating output due to widespread instantaneous wind cutout is not as dramatic as the sudden loss of a single large generating unit, there are transmission related issues that need to be addressed. These include high-speed wind cutout of plants as a storm front crosses through an area as well as the potential for long-lasting faults that have the possibility of tripping entire wind plants off-line.

3.10 Institutional Aspects of Natural Gas Transportation

While a robust transmission system can provide access to a significant amount of flexible resources, there may be institutional issues that can create barriers to using the available flexibility. These include the need to adhere to inter-area scheduling protocols that are intended to provide certainty to other control areas so that their operations can be managed in an orderly and controllable manner. Relying on the ability to import and export energy in the presence of large swings in variable generation is not an attractive alternative.

Like electrical transmission on the electrical network, transportation of natural gas must be managed and controlled to balance the supply and demand of natural gas at injection and delivery points. In the presence of large penetrations of wind resources, the differences between actual electric sector demand on the pipeline system and the anticipated day-ahead nomination schedule may become quite divergent. With the current level of relatively rigid nominations and delivery schedules, there may be reliability challenges to managing this

scheduling process. It may be prudent to advocate for additional gas pipeline scheduling and control technology to make the natural gas flows are more flexible.

3.11 Conclusion

Power systems have many sources of flexibility that are currently needed to maintain balance of supply and demand in anticipation of potential changes in system conditions. These changes can be expected and planned. For example, when morning load increases, it can require a dramatic and prompt increase in generation to follow loads. An unexpected change in the supply and demand balance can follow the loss of a large generating unit require fast acting generation or load response to return the system to balance. These flexibility needs are known and have been anticipated during the planning process. Additionally, there are long-term (i.e. daily, weekly and seasonal) concerns about balancing supply and demand that need to be addressed elsewhere¹⁰.

The primary finding from the this chapter is, although the integration of variable generation will result in greater overall system variability and increased need for flexibility, the power system of the future should be designed to achieve sufficient flexibility. However, many issues remain to be addressed and the challenge will be to identify the need for that flexibility and plan accordingly.

¹⁰ These forms of longer-term flexibility are typically satisfied by having energy stored in the form of solid, liquid or gaseous fuels that can be converted to electrical energy as needed through a conventional power plant or hydro electric facility. The need for these additional fuel-to-electricity resources is addressed in Task 1.2 (Capacity Value) which is concerned with the contribution of variable generation to satisfying a supply / demand balance during peak load conditions; absent dynamic disturbances to the power system or changes in variable generation output.

Chapter 4: Measuring Flexibility

4.1 Introduction

A modern electrical system must continuously maintain a balance between load and supply. To accomplish this, the system must have flexible resources, which can increase or decrease output to maintain this balance almost instantaneously. In this chapter, the characteristics of the imbalances between supply and demand that occur in an electrical system are defined. Metrics are proposed to measure these characteristics and can be mapped to the characteristics of flexible resources used to correct these imbalances. The set of metrics discussed below are presented to establish a starting point for the future development of a family of flexibility metrics that eventually can be incorporated into system planning tools to determine whether the planned system has sufficient flexibility to respond to the increased system variability, which will support targeted levels of variable generation.

4.2 Characteristics of Demand and Supply Imbalances and the Need for System Flexibility

A number of characteristics must be considered when describing imbalances of supply and demand, which are indications of the system needs for flexible resources. These can be grouped into three main areas:

Magnitude refers to both the size of ramp events and the direction of that event. Traditional reserve calculations sometimes measure the requirements as the size of the first and second contingencies. Incremental flexibility is required at times of facility outages and net load increases while decremental flexibility is required when net load decreases. On the supply-side, the magnitude is an indicator of the resources needed to respond to the ramp event.

Ramp Response refers to both the rate of change of the net load or unit output and their predictability. The ramp rate of the resources must be sufficiently large to be available to respond to system ramping needs. Large ramping events, which happen quickly will require fast acting, responsive resources or the simultaneous movement of a larger number of slower acting resources or a combination of both to meet the ramping needs of the system. Slower acting ramps, such as seasonal variations, require less responsive resources. Resources that can respond quickly would be labeled highly responsive ramping resources, while resources with slower response times would be labeled lower responsive ramping resources.

The ability to forecast load and variable generation with acceptable forecast error significantly affects the responsiveness of the flexible resource required to meet ramp requirements. The response to a forecast event can be quite different compared to an identical event occurring unexpectedly. Therefore, better forecasting results in a mix of the responsiveness of the resources that meet the ramping needs of the system while minimizing costs and required operating margins.

Frequency refers to the number of times events of various magnitudes and responsiveness occur. Variable resources generally increase the number of times flexible resources must be used in response to small or medium sized events. This is usually a cost issue as resources incur an operating cost each time they are used to balance supply and demand.

Available Flexible Resources determines the ability to change resources in response to imbalances between net load and total resources. The resources deployed must respond to the same event so the characteristics of the total response by all of the flexible resources are described by the aspects described above. Each individual resource will also have characteristics, which can be described by the aspects above.

4.3 Impact of Variable Generation on Imbalance and Net Load Ramping Characteristics

Over time, load patterns are largely well understood and forecast with high accuracy. The morning and evening demand ramp rates are large. However, they are well predictable so they have a low Ramp Response requirement. Less easily forecast load fluctuations are usually of a smaller Magnitude. Large Magnitude, unpredicted events are caused by equipment, generation or transmission failures, which can result in an undersupply situation.

Forecasted load duration curves give ramp rates, indicating the speed of the resource that needs to be available to meet it. Adding variable resources to the system mix decreases predictability and increases the variability in the net load. Because of this, the system will require more ramping capability to be available such as faster reacting, or higher ramp responsiveness, flexible resources.

Adding variable generation to a system will usually increase the Frequency of higher and medium magnitude events (see Chapter 2 and the examples in the Appendix). As the ability to forecast changes in variable generation increases, the required responsiveness will decrease. Systems with highly correlated variable resources could see an increase in the Frequency of large Magnitude and high Ramp Response events.

One of the more unique impacts of variable generation is an increase in the frequency of high and medium Magnitude events resulting in oversupply—variable generation coming onto the system quickly and unpredicted. These events are particularly problematic during night valleys when much of the Available Flexible Resource on line has little down ramp capability available.

4.4 Characteristics of Flexible Resources

This section will describe how the characteristics above apply to these resources (A variety of flexible resources available are described in Chapter 3). In most cases, these resources are physical equipment with well-defined characteristics to permit efficient dispatch. For most generation and demand-side resources, the Magnitude of the flexibility it can provide (capacity

above minimum load) and the Ramp Response (ramp rate in MW/minute either up or down) are standard quantities. Demand resources may only provide incremental or decremental flexibility.

The Frequency with which the resource responds is not usually restricted. However, interruptible loads are often limited in the number of times they can be called on, excessive cycling of base load plant causes wear and tear increasing the likelihood of outages, and energy constrained units are limited by the reservoir capacity and level. Some resources require significant lead times to start, which reduces the Ramp Response of the flexibility they offer. Unit synchronization time is the standard descriptor of this. Others are required to be at a minimum load (already synchronized) before they can offer flexibility.

4.5 Metrics for Load Ramping, Supply and Demand Imbalances and Flexible Resources

Metrics based on the net load are needed to indicate the resultant needs of the system. A framework of characteristics is provided above: Magnitude, Response and Frequency, which need to be captured in these metrics. These metrics will not be directly dependent on the penetration of variable generation. However, as shown in Chapter 2 and the examples in the Appendix, variable generation can be represented as changes to these metrics and hence the amount of flexible resources required.

In the operating timeframe, the two most commonly defined metrics for flexible resources are operating reserve usually divided into two or more categories based on speed of response and system regulation (automatic generation control). Operating reserves are designed to respond to the instantaneous loss of the largest source of supply, these are large Magnitude events with a high ramp requirement. Regulation is designed to respond to the second-to-second random fluctuations in load—high Frequency and Ramp Responsive but low Magnitude.

Chapter 2 presented the affects of Frequency of the various ramp Magnitudes on net load within one hour along with how this changes with the addition wind generation. The maximum positive or negative change gives the value for the Magnitude metric. It may be reasonable to exclude some observations if they should be considered extreme events or a reliability criterion similar to the Loss of Load Expectation is used. Similar to generation adequacy planning, this method assumes that if sufficient resources are available to meet the largest change, then smaller changes do not pose a threat to system reliability. The metric must also include the requirement for flexibility caused by equipment outages.

The Ramp Response characteristic includes the rate of ramping required from flexible resources and the predictability of the ramp. Measuring the maximum Magnitude change over various time scales (for example 10 min., 30 min., 1 hr., & 4 hrs.) and unit start up times would capture the rate of ramp aspect of Ramp Response. Predictability needs to include components such as event forecast accuracy and advance warning. Based on the resources described in Chapter 3, predictability can be divided into unpredicted random events (random net load fluctuations or equipment failures), forecasted (with errors, e.g. load and wind) or planned events (e.g. scheduled exchange).

The Frequency metric measures the frequency of ramp events of various sizes. A minimum amount of data includes the number and average size of positive and negative events. Minimum up and down times are a measure of the maximum frequency a conventional generator can be committed as a flexible resource. Measurement of the Frequency metric for energy constrained resources is a topic for further research. Most resources are not limited in their Frequency of use, however, so perhaps Frequency can be left unmeasured by a metric initially.

A resultant characteristic is the Intensity, which is a combination of the aspects of magnitude and ramp response. A large magnitude event over a very short period-of-time (responsive) would be a high intensity event. Conversely, a low magnitude event over any timeframe would be a low intensity event. In addition, a large magnitude event over a long period of time or one which was easily forecast would be a low intensity event. Events in between would be characterized as medium intensity events.

This sets a stage on an initial list of 24 metrics tabulated and illustrated below in Table 4-1:

Table 4-1: Illustration of Intensity Metric

Maximum +/- Ramp					Intensity
Random 10 Min.	Random Min.	30	Random 1 Hour	Random 4 Hours	HIGH
Forecast 10 Min.	Forecast Min.	30	Forecast 1 Hour	Forecast 4 Hours	MEDIUM
Planned 10 Min.	Planned 30 Min.		Planned 1 Hour	Planned 4 Hours	LOW

These metrics can largely be assembled solely from the pattern of net load adding the impact of equipment failures as a separate step. If the largest equipment failure will cause an event that is smaller than the maximum net load ramp there is not impact on the metrics. Eventually some of these metrics will dominate and some will provide no useful information. It is not obvious at this time which of the 24 metrics will fall into each category. This will become apparent with further study and experience of using these metrics.

Over each time scale of the metrics above and separately for positive and negative directions, the rated ramp can be calculated. This is what the flexible resources on the system must provide. It is a function of the time step, unit ramp rate and the maximum unit output—the Response aspects of the flexible resource. The unit synchronization time will also be relevant at longer time scales. If the sum of the resources available exceeds the metric there are sufficient flexible resources on the system. Some allowance will have to be made for forced

outages and the frequency with which a resource can be called on would have to be considered qualitatively.

4.6 Flexibility Resource Scheduling

Quantifying the flexible resource available in an operational time frame is more challenging. While, the individual flexibilities can be quantified e.g. ramping rates of thermal units, difficulties arise when modeling the operational aspects. For example the ramping up rate of a thermal unit is not available if the unit is dispatched at its maximum and vice versa the ramping down is not available if the unit is at its minimum operating point.

System operators must schedule sufficient flexible resources to meet the flexibility requirements continuously. The most efficient operational practices are those, which maximize the amount of flexibility available while minimizing cost. If operational aspects are not taken into account, from a planning point of view the system might well appear to have enough flexibility but operationally it cannot be accessed when needed. The question then becomes what kinds of additional modeling tools and metrics might be required beyond current practices to ensure that the flexibility requirements that result from variable generations are adequately captured in system planning studies.

There are no universally accepted metric or standard practices for explicitly capturing the concept of matching the resources to the requirements for flexibility, while ensuring that system adequacy is maintained within design criteria. A method, which is in its formative stage, is proposed here based on an adaptation of the Equivalent Load Carrying Capability (ELCC).¹¹ The Effective Ramping Capability (ERC) measures the flexible resource available to the system operator from conventional plant, in a planning context.

While the ELCC approximates a unit's contribution to meeting overall demand, the ERC attempts to approximate a unit's contribution to meeting net load changes. The ERC is a planning metric comprised of a set of values, describing a unit's contribution to the system's ability to ramp in a given direction over different time scales. Time steps can be chosen to match the data, which exists for a system or to the time steps used in reserve categories, such as 10 and 30 minutes. For example, the incremental 15-minute ERC is the additional active power a unit contributes to the system in 15 minutes, while the decremental 60 minute ERC is the decrease in unit output in 60 minutes. The ERC available to a power system then could be matched with needs as measured by the intensity distribution developed from the net-load ramps. As part of the calculation of ERC, one could prioritize units based on availability, relative operating costs, etc. to measure a variety of levels of available ERC providing a basis for planners and operators who may decide to obtain ramping from a variety of sources. Much work and proof-of-concept remains to be completed before this metric is available for use in planning studies.

¹¹ "Integration of Variable Generation: Capacity Value and Evaluation of Flexibility", IEEE PES, July 2010.

4.7 Summary - Measuring Flexibility

Approaches to measuring both the system need and the ability of resources to provide flexibility have been presented. This discussion can be viewed as the beginning of an industry initiative to develop a measure or measures of power system flexibility for use as both an operational and planning tool.

In the mean time, NERC should establish a set of metrics to support measurement of events requiring flexibility and the amount of flexibility available.

Chapter 5: Conclusions and Recommendations

As the penetration of variable generation increases, system flexibility requirements will also increase. This flexibility manifests itself in terms of the need for dispatchable resources to meet increased ramping and load following some of which could occur rather unexpectedly, i.e. not forecast. This flexibility will need to be accounted for in system planning studies to ensure system reliability. Enhancements to existing system planning practices will be required to account for increased flexibility necessitated by the integration of variable generation. System planning studies focus both on the reliability of the power system as well as optimizing the overall economics of the power system, here the emphasis is on reliability.

The primary data for assessing system flexibility requirements resulting from the integration of variable generation is the net load (load minus variable generation in all timeframes). Currently, there is no universally accepted measure or index of flexibility which would facilitate comparison across systems. The availability of such an index could potentially facilitate the evaluation of flexibility.

Current system planning practices and tools with appropriate modifications and enhancements have provided a basis for evaluating the impact of variable generation on system flexibility needs. For example, net load impacts can be evaluated explicitly or implicitly with tools such as a chronological production cost simulation model that typically model hourly operations and all relevant physical constraints including minimum generation levels ramp rates and transmission constraints. A number of recently completed studies whose objective was to evaluate the integration of variable generation have successfully used these models. These include studies by the California ISO Study, the Ontario Power Authority Study, the Electric Reliability Council of Texas (ERCOT) Study and more recently the Department of Energy, the Eastern Wind and Transmission Integration Study. All of the studies, to some extent, address how the variable generation impacts the need for system flexibility. The studies collectively covered the following aspects:

- Production cost models, which includes transmission models to assess the interaction between the dispatchability of wind and transmission.
- Extensive use of statistical analysis of hourly and sub-hourly wind plant output and net-load data (mainly simulated but some historical data was used where available) to ensure that production cost models adequately capture ramp rate and minimum generation constraints and account for regulation requirements.
- Wind forecast error models to account for operational impacts caused by the uncertain nature of variable generation (wind forecasting is covered by Task 2.1).¹²
- Resource adequacy models (e.g. LOLP models) that reflect the much lower availability or lower load carrying capability of variable generation (this topic is covered in detail by Task 1.2).¹³

¹² [http://www.nerc.com/docs/pc/ivgtf/Task2-1\(5.20\).pdf](http://www.nerc.com/docs/pc/ivgtf/Task2-1(5.20).pdf)

¹³ See Page 69 of http://www.nerc.com/files/IVGTF_Report_041609.pdf

In addition, these studies identified data needs specific to incorporating variable generation into planning studies:

- Determination of the interconnection point for the variable generation
- Specification for and identification of data sources, which facilitate the accurate modeling of variable generation resources.
- Models and associated data that enable the accurate simulation of the output of variable generation and ensure output profiles are contemporaneous with the load profile and represent the uncertainty in the profile.
- Data needed to conduct both transient and voltage stability analysis for wind plants.

Important planning topics such as system stability analysis and transmission planning are neglected by many of these studies but are recognized as important and needing attention. In particular the transmission planning that accounts for the flexibility needs is a topic that has hardly been addressed. For example, the more variable nature of power flows driven by the variable generation output may need to be addressed by a more integrated transmission and generation planning process.

Many of the studies found that the systems already possess the needed flexibility, particularly at lower variable generation penetration levels, and therefore there may be no need to develop additional sources of flexibility.

The integration studies should be reviewed to identify best practices and to develop guidelines that can be adopted immediately for the use of and enhancements to existing planning tools for evaluating the flexibility needs that arise from the integration of variable generation. It should be recognized in this review process that many important issues are simply not covered and require additional study and effort to develop meaningful guidelines.

In addition to identifying the impact of variable generation on the characteristics of system flexibility and their implication for system planning, this report also identified the many sources of increased flexibility available to system planners and operators. New sources such as demand side management may be particularly attractive and need further study. Many of the most important sources may not be physical, but institutional i.e. They unlock the availability of existing physical flexibility (e.g. forecasting, market design etc.). This indicates there is a portfolio of alternatives available to a power system to meet its flexibility requirements. These options would need to be evaluated within the context of any new enhanced system planning framework.

In summary, high penetrations of variable generation will result in the need for increased flexibility. This will require planning studies to account for this increased flexibility requirement. The report provides examples of how power systems that already have high levels of variable generation are adjusting operating practices and market structures in response to the increased variability. The report began the challenging effort of developing a metric for flexibility but leaves further development to NERC and industry. Finally, the report did not identify specific changes to planning practices to account for the impact of variable generation

but believes that a set of best practices to account for flexibility in planning studies now can be developed. A starting point for is a number of excellent integration of variable generation studies that have been conducted in the recent past.

Summary of Recommendations to NERC:

1. Probabilistic planning methods being developed in the ongoing work of NERC's IVGTF Task 1.6¹⁴ will be a vital improvement to assess required flexibility.
2. As part of developing the Variable Generation Reference Guide (Task 3.1) a set of best planning practices to design systems with sufficient system flexibility to accommodate targeted levels of variable generation should be documented.
3. NERC Reliability Metrics Working Group (RMWG) after provision of metric templates, develops agreed upon metrics:
 - Develop and collect metrics that measure flexibility needs for variable generation. For example, calculating a set of ramp and intensity metrics can provide insights on flexibility trends.
 - Compare projected and actual annual energy levels from variable generation
 - Measure variable generation performance factors such as capacity factors and peak coincidence factors

¹⁴ Summarized from the NERC Report, "Accommodating High Levels of Variable Generation," work plan: *Task 1.6: Probabilistic planning techniques and approaches* are needed to ensure that system designs maintain bulk power system reliability.

Appendix: Examples of Variable Generation Integration


Introduction

The purpose of this Appendix is to provide examples of power systems that are already dealing with the challenges of integrating variable generation resources and document the operational adjustments they are making to enhance operational flexibility in the presence of variable resources. Examples are provided from across North America as well as Europe.

BPA Example


As of November 2009, the Bonneville Power Administration (BPA) had 2,253 megawatts (MW) of installed wind capacity interconnected with its balancing authority (BA). With a peak net internal demand of 10,500 MW, this means that wind penetration in the BPA BA is over 20 percent of capacity. Over 75 percent of this wind generation is estimated to serve load outside of the BA. For the most part, BPA is required to firm this generation for export through the hour consistent with WECC’s current scheduling protocols. As shown in Figure A-1, the installed wind capacity interconnected into the BPA grid is likely to be over 10,000 MW by 2016 with an increasing percent age of wind generation exported to other BAs.

Figure A-1: BPA Wind Generation Forecast



Intra-hour wind balancing reserves are currently calculated based on a 30-minute persistence level of forecasting accuracy. In November 2009, BPA held nearly 31 percent incremental and 38 percent decremental reserves on an installed wind capacity basis to integrate wind generation into the BA. BPA has created the Wind Integration Team (WIT) to address the challenges of integrating high levels of wind generation into grid. The WIT technical members and sponsors are actively working with BPA customers and the wind development community on a number of efforts to effectively integrate wind generation into the grid. Success in a number of these efforts (Figure A-2) will result in lower intra-hour balancing reserves.

Figure A-2: BPA WIT Initiatives




The absolute level of these reserves, which are separated into the regulating (seconds), following (10-minute) and generation imbalance (GI—through the hour) timeframes is dependent on such factors as:

1. Wind generation forecasting accuracy
2. Operational controls, i.e. the ability of the BA to feather wind and/or curtail schedules if reserve levels are close to being exceeded
3. The scheduling interval through which wind generation for export needs to be firmed
4. The amount of wind generation that can be dynamically scheduled or pseudo-tied to other BAs

Flexible resources are mainly required to supply regulating and following reserves. Figure A-3 is an example of the variability of wind generation in the BPA BA.

Figure A-3: Wind Variability in BPA



BPA began tabulating ramp rates for the 5 minute, 30 minute and 60 minute increments, following are the maximum ramps experienced on an installed wind capacity basis:

1. 60-Minute Increment: 66.7 percent up and 48.8 percent down
2. 30-Minute Increment: 50.8 percent up and 49.4 percent down
3. 5-Minute Increment: 21.0 percent up and 48.4 percent down

It is the magnitude of these ramps in any wind regime, which dictate the amount of flexible resources needed. However, if wind generation forecasting methods are not sufficiently accurate to provide notice to the operator when these ramps might be expected, additional or extremely flexible power resources may be needed to address this uncertainty, including:

1. Construction of transmission infrastructure necessary to interconnect wind turbines and deliver generation to load
2. Improvements to capabilities to accurately forecast wind generation


AESO Example

The Alberta Electric System Operator (AESO) manages a fairly isolated system with limited interconnections to grids outside the province of Alberta, and therefore a limited ability to share balancing services. Additionally, the generation in the AESO is mainly large base-load coal-fired plants along with a significant amount of cogeneration. The AESO's peak load is

approximately 9,800 MW. Current wind capacity on the AESO system is approximately 500 MW, more than 5 percent of peak load by capacity. There is more than 12,900 MW of additional wind power projects in the AESO’s interconnection queue. Two recent wind power ramp events are described next.


May 21, 2009. Figure A-4 shows the AESO aggregate wind generation output and system load variation during a wind power ramp event that took place on May 21-22, 2009. Beginning at approximately 10:30 pm local time, wind power ramps approximately 310 MW over a 70-minute period while load decreased approximately 460 MW as part of the nightly load drop off. There was a coincident schedule increase in interchange of +120 MW, so that the net-demand change to be offset was about -650 MW (-460-310+120). The AESO operators had sufficient down ramping capability available to accommodate the up-ramp in the form of 100 MW from regulating reserves on units on AGC and 500 MW of energy market generation). Figure A-4 also shows, that within minutes of the up-ramp peaking, the wind generation began to ramp down, dropping 275 MW over the 140 minutes. Because the wind coincided with the still dropping load, it did not cause any operational issue. During the entire event, the largest ACE deviation reached 110 MW, which did not result in any NERC control performance standard (CPS2) violations. As such, the operators were able to manage the ramp event without any reliability implications because sufficient flexibility was available from other generation to accommodate the ramp.

Figure A-4: AESO Wind Power Output and System Demand during May 21, 2009



On July 30, 2009, AESO experienced a similar wind ramp event occurred on July 30, 2009, which is shown in Figure A-5. During this event, wind power ramps-up from about 50 MW at 18:40 to 325 MW at 19:04 or 275 MW in 25 minutes, and then back down to 100 MW at 20:14 (225 MW in 70 minutes). During that period, the interchange schedule did not change, and the load was also relatively flat. In response to the over-generation situation resulting from the up ramp and the potential that the wind would ramp further up to the full 500 MW capacity, the AESO system operator dispatched down about 480 MW of thermal capacity from the energy market merit order. Because of the magnitude and steepness of the up-ramp, regulating reserves and dispatch of the balancing reserves were not able to follow the ramp and a positive ACE of 177MW occurred, resulting in an over-generation Control Performance Standard (CPS) 2 violation. Subsequently, the wind down ramp that followed immediately coincided with the decreasing thermal generation in response to the operator dispatch, causing a negative ACE of -126 MW and another CPS2 violation for under-generation. In response to the under-generation condition, the system operator dispatched up about 420 MW of energy market capacity. In general, this event did not cause any serious reliability issue, but it did result in CPS2 violations and additional costs associated with balancing energy that was dispatched.

Figure A-5: AESO Wind Power Output during July 30, 2009 Ramp



ERCOT Example

As of January 2010, ERCOT has 8,916 MW of wind generation installed on its system. It is anticipated that with expansion of the transmission system via the Competitive Renewable Energy Zones (CREZ) that an additional 15,000 MW of wind generation may be added to the ERCOT system. Currently, ERCOT assumes that wind has an Effective Load Carrying Capability (ELCC) of 8.7 percent based on a Loss of Load Probability (LOLP) study completed in 2007. Based on this assumption, 776 MW is assumed to be firm capacity from wind generation in ERCOT. ERCOT is in the process of updating this analysis of LOLP and ELCC for wind.

In 2009, the wind has represented up to 25 percent of the load (on 10/28/2009 the load at 3am was 22,893 MW and the wind generation was 5,667 MW). The all-time peak of wind generation reached 6,223 MW on that same day. As shown in Figure A-6, ERCOT has experienced one hour swings of 3,039 MW increases (18-Apr-09 23:39 to 19-Apr-09 00:39) and Figure A-7 2,847 MW decreases (10-Jun-09 16:35 to 10-Jun-09 17:35).

Figure A-6: 3,039 MW increases (18-Apr-09 23:39 to 19-Apr-09 00:39)





Figure A-7: 2,847 MW decrease (10-Jun-09 16:35 to 10-Jun-09 17:35)




A detailed explanation of how another situation of wind variability was dealt with is summarized below.

February 26, 2008 Incident

ERCOT implemented Step Two of its Emergency Electric Curtailment Plan (EECP) on February 26, 2008 (Figure A-8). The primary factors leading to the implementation of the EECP was unavailable generation, which was counted as available in the ERCOT operational planning processes, and resulted in a deficiency of available generation during the evening load increase.

ERCOT tracks changes in the Resource Plan available capability and the load forecast through a tool called the Market Analyst Interface (MAI). This tool did not give any indication of the approaching capacity deficiency because it based its assessment of available capacity upon the Resource Plan data provided by the QSEs.

Figure A-8: Observations/Data Review 02/26/08 16:00 – 22:00 Load, Day-Ahead Load Forecast, ARR



ERCOT’s current system depends upon QSE submitted resource plans to calculate available capacity to analyze adequacy for coming hours. The Resource Plans reflected more generation capacity than was actually available, primarily accounted for by inaccurate wind energy expectations.


In addition to the MAI, ERCOT runs an hour-ahead study every hour to determine if there is adequate capacity to meet the demand. The results of this study are used to determine the need for Non-Spin deployments. This study did not indicate an approaching problem because the Resource Plans indicated approximately 1,000 MW capacity available that was subsequently unavailable.

The EECF event was triggered by rapid load growth beginning about 1800 which was paralleled by a matching drop in responsive reserve. As shown in this graphic, the load between 18:00 and 18:41 grew from ~33,000 MW to ~35,550 MW or an increase of about 2,550 MW. During this period ERCOT exhausted its available regulation up service and up balancing energy service.


Load Forecast

The hourly average day-ahead 19:00 load predicted was 35,619 MW (Figure A-9). The real-time hourly average load was 34,528 MW, below the day-ahead forecast by 1,091 MW. ERCOT experienced an instantaneous peak load of 35,863 MW at 18:52. Updated Resource Plans are hourly values captured during the operating hour.

Figure A-9: 02/26/08 15:00 – 21:00 Total Wind Output, Forecasts MW in the 16:00 Day-Ahead Resource Plan and Updated Resource Plan




The day-ahead resource plan did not forecast the magnitude of the drop in wind energy encountered. However, the 80 percent wind forecast that was developed for and will be incorporated into the Nodal system shown in green did predict the wind output with good fidelity (Figure A-10).

Figure A-10: Day-Ahead Market

This second graph shows that the updated resource plan for wind (captured 1 hour prior to each hour) and that incorporated into ERCOT's look-ahead planning tools was still showing large wind energy availability.


The illustration in Figure A-11 demonstrates the steady decline in energy available in the Balancing Energy stack, combined with the depletion of up-regulation service between 18:00 and the declaration of EECF at 18:41. As previously noted, ERCOT's look-ahead tools did not detect the approaching problem due to inaccurate input data from the resource plans.

Figure A-11: 02/26/08 18:00 – 19:30 Regulation, Remaining Balancing in Bid Stack, and Frequency



A non-spin deployment was issued at 18:28 due to the depletion of UBES stack and Up Regulation. Responsive Reserve was deployed five minutes later due to frequency dropping below 59.91 Hz (Figure A-12).

Figure A-12: 02/26/08 18:00 – 19:30 Non-Wind QSE SCE, Wind-Only QSE SCE, Non-Spin (NSRS) Deployment, Responsive Reserve (RRS) Deployment and Frequency




Note the large negative Schedule Control Error (SCE) in wind-only QSE's and lesser negative SCE of non-wind QSE's around 18:30 (SCE performance after deployment of Responsive Reserve – as shown in green, should probably not be considered because responsive reserve deployment does not honor QSE's ramp rates). Responsive reserve deployment at 18:33 briefly assisted frequency, but failed to restore it to 60 Hertz.

Day Ahead Replacement Reserve

The RPRS market study for the Operating Day of February 26, 2008 (Figure A-13, data in Table A-1) procured no units for congestion and capacity for the evening hours. The total hourly average on-line capacity at HE 19:00 in the RPRS market study was 38,693 MW; the actual hourly average on-line system capacity in real-time was 38,062 MW, less than the day-ahead resource plan capacity by 631 MW. There was an additional 600 MW of energy exported across the DC Tie that was not scheduled Day Ahead. For the hour ending 9:00 in the Day-Ahead Resource Plan wind generation was scheduled to generate 1,294 MW, real-time wind generation was approximately 335 MW when EECF was declared.

Figure A-13: 02/26/08 16:00 – 20:00 1-Hour-Average Real-Time Online Capacity and 1-Hour-Average Day-Ahead Online Capacity




	1-HR AVG Real-Time Online Capacity	1-HR AVG Day-Ahead Online Capacity
16:00	37,885	38,923
17:00	37,746	38,249
18:00	37,514	38,924
19:00	38,062	38,693
20:00	40,237	38,864

Table A-1

The response of Load Acting as a Resource (LaaRs) to deployment was generally good (Figure A-14). Only two failed to deploy within 10 minutes. It appears to be the deployment of LaaRs which halted frequency decline and restored ERCOT to stable operation.

Figure A-14: 02/26/08 18:30 – 19:30 LaaRs RRS Deployment




Action Steps

ERCOT shall determine requirements for early integration of the Nodal Wind generation forecast into the current Zonal operating system to incorporate the forecast in the short term planning applications in place of the Resource Plan values for wind. With earlier detection of approaching deficits, additional capacity can be procured so it is available when needed.

Midwest Independent System Operator Example

By the end of 2009, the registered wind capacity in MISO is 7,625MW. The peak load in MISO market territory in 2009 is 95,748MW. Figure A-15a shows the monthly (January 2009 to January 2010) wind generation and its percent age over the whole generation. Therefore, wind occupies a very small portion (1.6 percent to 4.2 percent) of total resources in MISO now.

Figure A-15a: Monthly Wind Use in MISO



But with the state wind mandate, MISO will see more wind units installed in MISO. Figure A-15b shows the RPS mandates in states within MISO territory.

Figure A-15b: State Renewable Portfolio Standards






Figure A-15c shows the potential wind in MISO in the next two years based on the wind units in MISO generation interconnection queue.

Figure A-15c: Potential Wind in MISO in Next 2 Years



The intermittent feature of the wind causes the large variation of daily wind output. Figure A-15d is the daily wind capacity factor for January 2010. The capacity factor varies from 5 percent to about 65 percent, while the Standard Deviation of the peak hour capacity factor is about 21.02 percent.

Figure A-15d: Daily Wind Capacity Factor of Jan 2010



The variable nature of wind provides no guarantee of wind on-peak capacity availability. Table A-2 lists the installed wind capacity and wind out at annual peak from 2005 to 2009.

The wind output at annual peak hour varies from 2 percent to 56 percent. Five-year average availability is 17 percent of nameplate capacity and the standard deviation is 23 percent. So how to count wind in resource adequacy study is a big issue in the future if MISO integrates more wind capacity in the system. MISO is working with its stakeholders to decide the appropriate wind capacity credit to be used for the annual winter and summer assessment, and planning reserve requirement evaluation. For 2010, based on the LOLE and ELCC study, MISO will use 8 percent as wind capacity credit.

Table A-2 Wind at Annual Peak

Planning Year	Wind MW at Peak	Registered Max MW	% of Max
2005	104	907	11.47%
2006	700	1,251	55.96%
2007	44	2,064	2.13%
2008	384	3,085	12.45%
2009	78	5,635	1.38%
Average			16.68%
Std. Deviation			22.55%

In MISO, there was no serious event caused by the wind experienced due to the low percentage of wind in the current system. But MISO has experienced some wind events. Figure A-15e and Figure A-15f show one of such kind of event happened in March 17 2009. From 8:50am to 9:50am, in 60 minutes, see 825 MW wind dropped out. From 9:32am to 9:47am, within 15 minutes, the wind output dropped 306 MW.

Figure A-15e March 17 2009 Wind Event in MISO (60 minutes change)






Figure A-15f: March 17 2009 Wind Event in MISO (15 minutes change)



March 17, 2009 events did not cause any problem in MISO system, as MISO system has enough ramp and regulation capabilities to cover this change, though at that time, MISO had about 4,000 MW registered wind resources in the system. If MISO considers the current states' RPS mandate, about 22,500MW wind will be added in MISO by 2027. In addition, if MISO considers the potential Federal 20 percent RPS mandates, the system could have 40,000MW wind by 2027.

If the wind is assumed to follow the same 5 minutes change as in March 17 2009, Figure A-15g shows the 5 minutes wind output change in MISO system under 4,000MW (current), 22,500MW (current states RPS mandates), and 40,000MW (Federal 20 percent mandates) wind capacity. The 5 minutes wind down-ramp would reach 2,400MW in 40,000MW scenario, indicating that MISO may need more ramp and regulation capabilities.

Figure N-1g: Actual and Potential 5 Minutes Change in Wind Output



New York Independent System Operator Example

The New York Independent System Operator (NYISO) is the system operator for the New York Balancing Area, which encompasses the entire State of New York. It also operates the State's wholesale electricity market. The primary mission of the NYISO is as follows

1. Reliability

Managing the efficient flow of power on over 10,775 miles of high-voltage transmission lines -- from more than 500 generating units -- on a minute-to-minute basis, 24 hours-a-day, seven days-a-week. The installed resource base in New York exceeds 40 GW and the all time summer system peak was 33,939 MW.

2. Markets

Administering and monitoring competitive wholesale electricity markets totalling \$11 billion annually -- running auctions that match the buyers and sellers of power

3. Planning

Conducting long-term assessments of the Empire State's electricity resources and needs

New York State adopted a Renewable Portfolio Standard, which requires 25 percent of New York States' electricity needs to be supplied by renewable resources by 2013. This requirement includes existing hydro plants that provide about 17 percent of NY's electricity requirements. Future increases in renewables to meet the full requirements of the target are expected to be met by wind plants. This requirement resulted in a study, which was designed to conduct a comprehensive assessment of wind technology and to perform a detailed technical study to evaluate the impact of large-scale integration of wind generation on the New York Power System (NYPS). The study was conducted by GE Power System Energy Consulting in fall of 2003 and completed by year end 2004 (i.e., "the 2004 Study").

The overall conclusions from 2004 Study is the expectation that the NYPS can reliably accommodate up to a 10 percent penetration of wind generation or 3,300 MW with only minor adjustments to and extensions of its existing planning, operation, and reliability practices – e.g., forecasting of wind plant output. Since the completion of the 2004 Study, a number of the recommendations contained in the report have been adopted. They include the adoption of a low voltage ride through standard, a voltage performance standard and the implementation of a centralized forecasting service for wind plants.


Installed nameplate wind generation has now has grown to in excess of 1,200 MW and the NYISO interconnection queue significantly exceeds the 3,300 MW that was studied in the 2004 Study. In addition, the State of New York has increased its RPS standard to 30 percent by 2015. One of the observations made in the 2004 Study was that much could be learned from operating wind plants as they came on line. This would be a point in time that wind penetrations levels would be minimal and operating adjustments could be made based on those experiences. To that end, the NYISO has gained much experience from operating wind plants.

Besides the experience gained from day-to-day operation of wind plants, the NYISO has been able to experience and analyze rare events such as high speed cut out and how wind plants respond to real-time prices. High speed cut out is the result of wind conditions that exceed the capability of the wind turbines and they need to shut down rapidly to protect the equipment. They can also ramp up quickly as the wind speed picks up suddenly. Wind plants generally participate as price takers in the real time market. In NY, prices are allowed to go negative.


Wind plants will ramp up quickly as thunderstorm approaches a plant site and then shut down as wind speed exceeds the capability of the equipment. Figure A-16 below is an example of a high speed cut out event that NYISO operations observed on June 10, 2008. The figure shows for five-minute time steps how a front containing thunderstorms moved from east to west across the Northern portion of the NYCA affecting wind plants at different locations on the

system. Wind plant output is expressed as a percent of nameplate. For the first set of plants (red line) to encounter the front, the plants ramp up preceding the cutouts from 26 percent of nameplate to 61 percent of nameplate over 30 minutes and then ramp down from cutouts to 5 percent of nameplate over 10 minutes. After the storm passes, the plants ramp back up to 82 percent of nameplate over 45 minutes. A similar pattern is observed later for the plants further to the east (green line). These changes in output were able to be addressed within the NYISO's market-based Security Constrained Economic Dispatch (SCED) systems which includes a scheduling/dispatch update every five minutes.

Figure A-16: High Speed Cut-out Event approx. 12 noon on 6/10/08. The red line is wind plants in Northwest Central NY and Green line are wind plants in Northeastern NY



In addition, the NYISO has observed the ability of wind plants to adjust the level of their output rapidly in response to changing system conditions, which can result in price changes. As an example, on May 15, 2007 five-minute prices at the generator bus or interconnection point of one of New York's wind plants spiked as low as -\$4000 per MWh. Figure A-17 displays the plants response to these prices. The plant reduced its output from 80 percent of nameplate to almost zero in a little over two minutes. This cleared the congestion problem. However, the plant only needed to move to about 60 percent of nameplate to clear the congestion. This was the result of the wind plant not being supplied information as the appropriate generation level to clear congestion.

Figure A-17: Wind Plant Response to Negative Prices

The day-to-day experience wind events in conjunction with these atypical operating experiences with wind plants has indicated a need to communicate dispatch commands to the wind plant operators on an as needed basis to help maintain system reliability and prevent unnecessary plant shut downs. This will become even more important as the amount installed wind plant MWs increase of above current levels.

As result of these experiences, the NYISO working with market participants became the first grid operator to be approved by the Federal Energy Regulatory Commission to fully integrate wind resources with economic dispatch of electricity. The NYISO's wind resource management initiative is designed to extend its market-based Security Constrained Economic Dispatch (SCED) systems to wind plants to facilitate maintaining reliability and achieve the following goals:

1. Facilitate the integration of wind plants by using the NYISO's market signals (e.g. location-based marginal prices) and the economic offers submitted by the generation resources, including wind plants, to address reliability issues rather than relying upon manual intervention by the operators or the unanticipated response of wind plants, which could exacerbate the condition.
2. Based on the offers submitted by each wind plant and other resource, SCED determines the economic mix of resources to meet real-time security constraints. This results in the

NYISO or local system operators taking less efficient and out-of-market actions to protect the reliability of the system absent wind resources being dispatched by security-constrained dispatch (SCD).

3. The result is better use of wind plant output while maintaining a secure, reliable system and more transparent LBMP signals.


The NYISO integration of wind resources was facilitated by its interconnection requirements that wind plants supply a full set of data to the NYISO by way of the local transmission operators' supervisory control and data acquisition systems. This data set now includes meteorological data for the plant site. In addition to incorporating wind plants into SCED the NYISO has developed new market rules to facilitate new energy storage systems such fly-wheels and batteries to participate in ancillary services such as regulation.

In conclusion, the levels of wind-generating resources will be needed to meet New York's RPS standards will pose increased operating challenges on a day-to-day basis. However, the NYISO conclusions is that these challenges can be addressed through the operational processes already in place, enhancement to these processes as required and through system reinforcements as needed. This conclusion assumes that sufficient resources to meet the increased flexibility needs that results from variable generation will be available.

European Examples

DENMARK and IRELAND


Denmark and Ireland (Figure 17) are similar systems (both 7 GW installed capacity) with large amounts of wind power (Denmark, 3.2 GW, 20 percent energy; Ireland 1.4 GW, 11 percent energy) and much can be learned from a flexibility perspective by analyzing their specific operational characteristics (Figure 18). Denmark is well connected to two large synchronous systems with relatively little wind Continental Europe (640GW; Wind 45GW; Interconnection 950/1500 MW) and to Nordic system (90 GW; Wind 2.5GW; Interconnection 1300/1700MW). Denmark makes extensive use of these larger systems, good interconnection and fast balancing markets to balance the wind. In particular, the Nordic system has a lot of flexible Hydro generation. Ireland in contrast is a synchronous power system itself and is weakly connected to the larger Great Britain system (60GW; Wind 3GW; Interconnection 500MW). Ireland mainly uses flexible thermal plant to balance the wind (Figure 19).



Source: (A) www.energinet.dk; (B) www.eirgrid.com

Figure A-17: Wind Energy, Electricity Demand, and Instantaneous Penetration Level in (a) West Denmark for a Week in January 2005, and (b) Ireland for 3 Days in November 2009

(a) Unscaled Load Duration Curve



(b) Scaled Load Duration Curve





Figure A-18: Load Duration Curves for Ireland in (a) 2008, and (b) Projected for High Wind Energy Penetration Levels¹⁵. Source: www.eirgrid.com

¹⁵ Projected penetration level curves are based on scaled of 2008 data (demand is scaled by 1.27 and wind is scaled on average by 7). Ramp duration curves show the cumulative probability distributions of 15-minute changes in demand and net demand.

(a) Unscaled Delta Distribution



(b) Scaled Delta Distribution¹




Figure 19: 15 minute (a) unscaled and (b) scaled load and net load ramp distributions for the Republic of Ireland

FRANCE

System with large amounts of Nuclear Generation:

Nuclear power is generally base loaded with little or no flexibility. As more variable generation is installed with systems with large amounts of nuclear it may become necessary for nuclear to become more flexible. The French electric system with approximately 80 percent of

its electrical energy generated from Nuclear power is an interesting test case to study flexibility in nuclear power. France has very small but growing wind penetration. However, at the moment, the French nuclear fleet are effectively base loaded continuously and do not provide any flexibility. The French system manages variability with a combination of interconnection and other plant (hydro and thermal).

SPAIN

Solar:

Spain has found that solar has also increased the need of flexibility in our system. There are around 3,500 MW of solar PV installed and 300 MW of solar thermal. In the case of solar PV all but 52 MW are connected to the distribution level whereas solar thermal is connected normally to the transmission level with a ratio of around 70/30. Solar power has produced last year in Spain 5347 GWh, which is about 2 percent of the total energy consumed in the country with an average utilization factor of 1450 hours a year or 16 percent.

The biggest problem in Spain with solar PV is the lack of observability as plants do not have the requirements that apply to other renewable and do not have the obligation of sending us real-time information about their production. Spain currently has real-time measurements of about 150 MW though the figure is desired to be higher, with the help of the distribution companies, so a good estimate of their production could be built. Right now Spain uses meteorological predictions to estimate how much solar PV exists each hour. In the case of solar thermal, Spain has real-time information of all plants.

Currently the variability of solar PV production is not affecting the system as it is not bigger than the demand fluctuations so it is actually perfectly dealt with by the secondary regulation. This is probably due to a portfolio effect as solar plants have actually been installed almost everywhere in Spain except for the northernmost provinces.

However in terms of slower reserves, solar PV is also affecting them as production during a cold sunny winter day can be as high as 2,500 MW during the middle hours of the day but decreases suddenly as the sun sets and exactly at this time of the day the demand starts to increase to the daily peak load. If the wind and the hydro are presenting high productions, the downward reserve margin during the middle hours of the day might be tight since the thermal groups needed to supply the peak demand of the day must already be switched on in order to be able to reach full power during the peak.

Another problem with solar PV is the lack of voltage dip ride through capability, but since it is connected to the distribution levels it is not usually affected by faults that are far away and the use of full-converters make them less sensible to voltage dips as the first DFIG wind generators were. Nonetheless, the regulator is being requested to pass some regulation so that they must also comply with the present grid code for wind.

GERMANY

Flexibility here means e.g. fast acting thermal plant, storage and good transmission infrastructure to access the flexibility etc. Germany has plenty of examples with wind but little experience with solar. Germany has 1 percent of its electrical energy from solar power (7-8 GW of installed PV) so it is a world leader in integrating solar.

There are 8,550 MW all PV, no solar thermal plants in Germany producing about 1.3 percent of energy consumption. Almost all PV is on the distribution level, mostly in small units (2 - 100 kW), with the largest unit at 52 MW. Due to the wide distribution all over the country in very small units, sudden changes aren't possible. All four German Transmission Service Operators have published data for all German Renewable Energy Standards, which are operating under the renewable energy act. This includes wind, PV, biomass, small hydro etc.

IVGTF Task Force 1-4 Roster

Co-Chair	Michael Milligan Consultant	National Renewable Energy Laboratory 1617 Cole Blvd Golden, Colorado 80401	(303) 384-6927 (303) 384-6901 Fx michael.milligan@nrel.gov
Co-Chair	Mark O'Malley Professor of Electrical Engineering	University College Dublin R. 157A Engineering & Materials Science Centre University College Dublin, Belfield Dublin 4,	00353-1-716-1851 00353-1-283-0921 Fx mark.omalley@ucd.ie
	John M. Adams Principal Electric System Planner	New York Independent System Operator 3890 Carman Road Schenectady, New York 12303	(518) 356-6139 (518) 356-6208 Fx jadams@nyiso.com
	Bagen Bagen Exploratory Studies Engineer	Manitoba Hydro 1146 Waverley St-Bay12 Winnipeg, Manitoba R3C 0P4	(204) 474-3958 (204) 477-4606 Fx bbagen@hydro.mb.ca
	Kieran Connolly Manager, Generation Scheduling	Bonneville Power Administration 905 NE 11th Avenue Portland, Oregon 97232	(503) 230-4680 (503) 230-5377 Fxkpcconnolly@bpa.gov
	Wayne H Coste Principal Engineer	ISO New England, Inc. One Sullivan Road Holyoke, Massachusetts 01040-2841	(413)540-4266 (413)540-4203 Fx wcoste@iso-ne.com
	William C Crews, P.E. Regional Planning Assessment Engineer, Sr.	Texas Regional Entity	512-275-7533 curtis.crews@texasre.org
	Kevin Hanson Supervisor, Resource Planning	Electric Reliability Council of Texas, Inc. 2705 West Lake Drive Taylor, Texas 76574	(512) 248-6586 (512) 248-4235 Fx khanson@ercot.com
	David Jacobson Interconnection & Grid Supply Planning Engineer	Manitoba Hydro 12-1146 Waverly Street P.O. Box 815 Winnipeg, Manitoba R3C 2P4	(204) 474-3765 (204) 477-4606 Fx dajacobson@hydro.mb.ca
	Kevan Jefferies Manager - Market Forecasts and Modeling	Ontario Power Generation Inc. 700 University Avenue Toronto, Ontario M5G 1X6	(416) 592-3390 (416) 592-6071 Fx kevan.jefferies@opg.com
	Hardev S. Juj Manager, Transmission System Operations	Bonneville Power Administration ,	(360) 418-8981 hsjuj@bpa.gov

	William B Kunkel Senior Engineer	Midwest Reliability Organization 2774 Cleveland Ave N Roseville, Minnesota 55113	(651) 855-1717 (651) 343-6966 Fx wb.kunkel@midwestreliability.org
	Warren Lasher Manager, System Assessment	Electric Reliability Council of Texas, Inc. 2705 West Lake Drive Taylor, Texas 76574	(512) 248-6379 (512) 248-4235 Fx wlasher@ercot.com
	Clyde Loutan Senior Advisor - Planning and Infrastructure Development	California ISO 151 Blue Ravine Road Folsom, California 95630	(916) 608-5917 (609) 452-9550 Fx cloutan@caiso.com
	Ming Ni Manager, Economic Studies	Midwest ISO, Inc. 1125 Energy Park Drive Saint Paul, Minnesota 55108	(651) 632-8449 (651) 788-0101 Fx mni@midwestiso.org
	Bradley M. Nickell Renewable Integration and Planning Director	Western Electricity Coordinating Council 615 Arapeen Drive Suite 210 Salt Lake City, Utah 84108	(801) 455-7946 (661) 822-5991 Fx bnickell@wecc.biz
	Jeff Nish Director, Resource Adequacy	Alberta Electric System Operator 2500, 330-5th Avenue S.W. Calgary, Alberta T2P 0L4	(403) 539-2580 (403) 539-2795 Fx jeff.nish@aeso.ca
	Mahendra C Patel Senior Business Solutions Engineer	PJM Interconnection, L.L.C. PJM Interconnection, LLC 955 Jefferson Avenue Norristown, Pennsylvania 19403	(610) 666-8277 (610) 666-2296 Fx
	Mikael Backman Director, Market Development	Wartsila North America Inc 900 Bestgate Rd Annapolis, Maryland 21401	410-573-9755 410-573-2100 Fx Mikael.backman@wartsila.com
Observer	Aaron Bennett Reliability Assessments Engineer	North American Electric Reliability Corporation 116-390 Village Boulevard Princeton, New Jersey 08540-5721	(609) 452-8060 (609) 452-9550 Fx aaron.bennett@nerc.net
Observer	Daniel Brooks Manager, Power Delivery System Studies	Electric Power Research Institute 942 Corridor Park Blvd. Knoxville, Tennessee 37932	(865) 218-8040 (865) 218-8001 Fx dbrooks@epri.com
Observer	Eric John Vice President, Electric Utility Projects	SkyFuel Inc. 10701 Montgomery Boulevard Suite A Albuquerque, New Mexico 87111	(505) 999-5823 (505) 323-2747 Fx eric.john@skyfuel.com
Observer	Yuri Makarov Chief Scientist - Power Systems	Pacific Northwest National Laboratory 902 Battelle Boulevard P.O. Box 999 Richland, Washington 99352	(504) 375-2266 (504) 375-2266 Fx yuri.makarov@pnl.gov

Observer	Srijib Kantha Mukherjee Principal Advisor	Quanta Technology 4020 Westchase Boulevard Suite 300 Raleigh, North Carolina 27607	(919) 334-3028 (919) 538-5348 Fx smukherjee@quanta-technology.com
Observer	Subbaiah Pasupulati Director of Technical Studies	Oak Creek Energy Systems, Inc. 14633 Willow Springs Road Mojave, California 93501	(909) 241-9197 (661) 822-5991 Fx subbaiah@oakcreekenergy.com
Observer	Richard Piwko Director	GE Energy One River Road Bldg. 2-644 Schenectady, New York 12345	(518) 385-7610 richard.piwko@ge.com
Observer	Pouyan Pourbeik Technical Executive	EPRI 942 Corridor Park Boulevard Knoxville, Tennessee 37932	(919) 806-8126 ppourbeik@epri.com
Observer	Henry Tilghman Director	Vestas Americas 1881 SW Naito Portland, Oregon 97201	(503) 327-7499 hetil@vestas.com
Observer	Robert Zavadil Vice President and Principal Consultant	EnerNex Corp 620 Mabry Hood Road Suite 300 Knoxville, Tennessee 37932	(865) 218-4600 Ext. 6149 (865) 218-8999 Fx bobz@enernex.com

North American Electric Reliability Corporation Staff

North American Electric Reliability Corporation
116-390 Village Boulevard
Princeton, New Jersey 08540-5721

Telephone: (609) 452-8060
Fax: (609) 452-9550

Reliability Assessment and Performance Analysis

NERC Staff	Mark G. Lauby Director of Reliability Assessment and Performance Analysis	(609) 452-8060 (609) 452-9550 Fx mark.lauby@nerc.net
NERC Staff	Rhaiza Villafranca Technical Analyst	(609) 452-8060 (609) 452-9550 Fx rhaiza.villafranca@nerc.net