

Standard Development Timeline

This section is maintained by the drafting team during the development of the standard and will be removed when the standard is adopted by the NERC Board of Trustees (Board).

Description of Current Draft

This is the first draft of the proposed standard.

Completed Actions	Date
Standards Committee approved Standard Authorization Request (SAR) for posting	January 20, 2021
SAR posted for comment	July 08 – August 06, 2021
SAR posted for comment	January 11 – February 09, 2022
45-day formal comment period with ballot	October 25 – December 09, 2022

Anticipated Actions	Date
45-day formal comment period with additional ballot	February 22 – April 03, 2023
10-day final ballot	April 17 – April 27, 2023
Board adoption	May 2023

A. Introduction

1. **Title:** Reliability Coordinator Data [and Information](#) Specification and Collection
2. **Number:** IRO-010-[54](#)
3. **Purpose:** To prevent instability, uncontrolled separation, or Cascading outages that adversely impact reliability, by ensuring the Reliability Coordinator has the data [and information](#) it needs to [plan](#), Monitor and assess the operation of its Reliability Coordinator Area.
4. **Applicability**
 - 4.1. Reliability Coordinator
 - 4.2. Balancing Authority
 - 4.3. Generator Owner
 - 4.4. Generator Operator
 - 4.5. Transmission Operator
 - 4.6. Transmission Owner
 - 4.7. Distribution Provider
5. **Effective Date:** See Implementation Plan for Project 2019-06.

B. Requirements

- R1. The Reliability Coordinator shall maintain a documented specification for the data [and information](#) necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. The ~~data~~ specification shall include but not be limited to: (*Violation Risk Factor: Low*) (*Time Horizon: Operations Planning*)
 - 1.1. A list of data and information needed by the Reliability Coordinator to support its Operational Planning Analyses, Real-time monitoring, and Real-time Assessment, including non-BES data and [information](#), external network data [and information](#), [and identification of the applicable entities responsible for responding to the specification](#) as deemed necessary by the Reliability Coordinator.
 - 1.2. Provisions for notification of current Protection System and Remedial Action Scheme (RAS) status or degradation that impacts System reliability.
 - 1.3. Provisions for notification of BES generating unit(s) during local forecasted cold weather to include:
 - 1.3.1 Operating limitations based on:
 - 1.3.1.1. capability and availability;
 - 1.3.1.2. fuel supply and inventory concerns;

1.3.1.3. fuel switching capabilities; and

1.3.1.4. environmental constraints

1.3.2. Generating unit(s) minimum:

1.3.2.1. design temperature; or

1.3.2.2. historical operating temperature; or

1.3.2.3. current cold weather performance temperature determined by an engineering analysis.

1.4. Provisions for the identification of any data and information where the responsible respondent identified in Part 1.1 will utilize an applicable entity as an intermediary to pass through the data and information unaltered from the entities that originated the data and information.

1.5. Protocols for the responsible respondent identified in Part 1.1 to provide data and information that includes, but is not limited to:

1.5.1 Specific deadlines or periodicity in which data and information is to be provided;

1.5.2 Performance criteria for the availability and accuracy of data and information, as applicable;

1.5.3 Provisions to update or correct data and information, as applicable or necessary.

1.6. Identification of the mutually agreed upon format.

1.7. Identification of the mutually agreed upon process for resolving conflicts between the Reliability Coordinator, the responsible respondent identified in Part 1.1 that has the required data and information, and if necessary, the intermediary.

1.8. Identification of the mutually agreed upon security protocol or method for securely transferring data and information.

~~The deadline by which the respondent is to provide the indicated data.~~

M1. The Reliability Coordinator shall make available its dated, current, in force documented specification for data and information.

R2. The Reliability Coordinator shall distribute its data and information specification to entities that have data required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. (*Violation Risk Factor: Low*) (*Time Horizon: Operations Planning*)

M2. The Reliability Coordinator shall make available evidence that it has distributed its ~~data~~ specification to entities that have data and information required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and

Real-time Assessments. This evidence could include but is not limited to web postings with an electronic notice of the posting, dated operator logs, voice recordings, postal receipts showing the recipient, date and contents, or e-mail records.

- R3.** Each Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a **data** specification in Requirement R2 shall satisfy the **obligations of the documented specifications using [the criteria established in Requirement Parts 1.5 through 1.8](#): (Violation Risk Factor: Medium) (Time Horizon: Operations Planning, Same-Day Operations, Real-time Operations)**

~~**3.1.** A mutually agreeable format~~

~~**3.2.** A mutually agreeable process for resolving data conflicts~~

~~**3.3.** A mutually agreeable security protocol~~

- M3.** The Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Reliability Coordinator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a **data** specification in Requirement R2 shall make available evidence that it satisfied the obligations of the documented specification using the specified criteria. Such evidence could include but is not limited to electronic or hard copies of data transmittals or attestations of receiving entities.

C. Compliance

1. Compliance Monitoring Process

- 1.1. Compliance Enforcement Authority:** “Compliance Enforcement Authority” (CEA) means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with the mandatory and enforceable Reliability Standards in their respective jurisdictions.
- 1.2. Evidence Retention:** The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the CEA may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider shall each keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The Reliability Coordinator shall retain its dated, current, in force documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments for Requirement R1, Measure M1 as well as any documents in force since the last compliance audit.

The Reliability Coordinator shall keep evidence for three calendar years that it has distributed its data specification to entities that have data required by the Reliability Coordinator’s Operational Planning Analyses, Real-time monitoring, and Real-time Assessments for Requirement R2, Measure M2.

Each Reliability Coordinator, Balancing Authority, Generator Owner, Generator Operator, Transmission Operator, Transmission Owner, and Distribution Provider receiving a data specification shall retain evidence for the most recent 90-calendar days that it has satisfied the obligations of the documented specifications in accordance with Requirement R3 and Measurement M3.

- 1.3. Compliance Monitoring and Enforcement Program:** As defined in the NERC Rules of Procedure, “Compliance Monitoring and Enforcement Program” refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated reliability standard.

Violation Severity Levels

R#	Time Horizon	VRF	Violation Severity Levels			
			Lower	Moderate	High	Severe
R1	Operations Planning	Low	The Reliability Coordinator did not include two or fewer of the parts (Part 1.1 through Part 1.85) of the documented specification for the data <u>and information</u> necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.	The Reliability Coordinator did not include three <u>to four</u> of the parts (Part 1.1 through Part 1.85) of the documented specification for the data <u>and information</u> necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.	The Reliability Coordinator did not include <u>five to seven</u> our of the parts (Part 1.1 through Part 1.85) of the documented specification for the data <u>and information</u> necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.	The Reliability Coordinator did not include any of the parts (Part 1.1 through Part 1.85) of the documented specification for the data <u>and information</u> necessary for it to perform its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. OR, The Reliability Coordinator did not have a documented specification for the data necessary for it to perform its Operational Planning Analyses, Real-time

						monitoring, and Real-time Assessments
<p>For the Requirement R2 VSLs only, the intent of the SDT is to start with the Severe VSL first and then to work your way to the left until you find the situation that fits. In this manner, the VSL will not be discriminatory by size of entity. If a small entity has just one affected reliability entity to inform, the intent is that that situation would be a Severe violation.</p>						
R2	Operations Planning	Low	<p>The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to one entity, or 5% or less of the entities, whichever is greater, that have data and information required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.</p>	<p>The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to two entities, or more than 5% and less than or equal to 10% of the reliability entities, whichever is greater, that have data and information required by the Reliability Coordinator's Operational Planning Analyses, and Real-time monitoring, and Real-time Assessments.</p>	<p>The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to three entities, or more than 10% and less than or equal to 15% of the reliability entities, whichever is greater, that have data and information required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.</p>	<p>The Reliability Coordinator did not distribute its data specification as developed in Requirement R1 to four or more entities, or more than 15% of the entities, whichever is greater, that have data and information required by the Reliability Coordinator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.</p>

<p>R3</p>	<p>Operations Planning, Same-Day Operations, Real-time Operations</p>	<p>Medium</p>	<p>The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to follow use one of the criteria shown in <u>Requirement R1</u> Parts <u>13.51</u> – <u>13.83</u>.</p>	<p>The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to use follow two of the criteria shown in <u>Requirement R1</u> Parts <u>13.51</u> – <u>13.83</u>.</p>	<p>The responsible entity receiving a data specification in Requirement R2 satisfied the obligations of the documented specifications for data but failed to use follow any three or more of the criteria shown in <u>Requirement R1</u> Parts <u>13.51</u> – <u>13.83</u>.</p>	<p>The responsible entity receiving a data specification in Requirement R2 did not satisfy the obligations of the documented specifications for data.</p>
------------------	---	---------------	---	---	--	---

D. Regional Variances

None

E. Interpretations

None

F. Associated Documents

None

Version History

Version	Date	Action	Change Tracking
1	October 17, 2008	Adopted by Board of Trustees	New
1a	August 5, 2009	Added Appendix 1: Interpretation of R1.2 and R3 as approved by Board of Trustees	Addition
1a	March 17, 2011	Order issued by FERC approving IRO-010-1a (approval effective 5/23/11)	
1a	November 19, 2013	Updated VRFs based on June 24, 2013 approval	
2	April 2014	Revisions pursuant to Project 2014-03	
2	November 13, 2014	Adopted by NERC Board of Trustees	Revisions under Project 2014-03
2	November 19, 2015	FERC approved IRO-010-2. Docket No. RM15-16-000	
3	February 6, 2020	Adopted by NERC Board of Trustees	Revisions under Project 2017-07
4	TBD	Adopted by NERC Board of Trustees	Revisions under Project 2019-06 Cold Weather
3	October 30, 2020	FERC approved IRO-010-2. Docket No. RD20-4-000	
4	June 11, 2021	Adopted by NERC Board of Trustees	Revisions under Project 2019-06
4	August 24, 2021	FERC approved IRO-010-4 Docket No. RD21-5-000	
4	August 24, 2021	April 1, 2023	Effective Date
		TBD	TBD