

Implementation Plan for MOD-024-2

Prerequisite Approvals

There are no other Reliability Standards or Standard Authorization Requests (SARs), in progress or approved, that must be implemented before this standard can be implemented.

MOD-024-2 — Verification and Data Reporting of Generator Real Power Capability

Revision to Sections of Approved Standards and Definitions

There are no proposed revisions to requirements in other already approved standards. There are no new definitions in the proposed standard.

Compliance with Standard

The standard applies to Generator Owners, Planning Coordinators and Resource Planners.

Effective Date

All requirements of MOD-024-2 become effective the first day of the first calendar quarter six months after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, the standard shall become effective on the first day of the first calendar quarter six months after Board of Trustees adoption.

Verification requirements in this standard cover the summer and winter peak periods; the compliance monitoring:

- for units to be verified annually per MOD-024-2 Attachment 1 — Verification of Summer and Winter Generating Unit Capability, section number 4, will begin 30 calendar days following the first summer or winter peak period that begins at least 60 calendar days following the effective date.
- for units to be verified every five years per MOD-024-2 Attachment 1 — Verification of Summer and Winter Generating Unit Capability, section number 4, will begin five years after the compliance implementation date for annual units.