

## Project 2010-14.1 Mapping Document Transition of BAL-002-0 to BAL-002-2

Standard: BAL-002-0 — Disturbance Control Standard		
Requirement in Approved Standard	Transitions to the below Requirement in New Standard or Other Action	Description and Change Justification
BAL-002-0 R1	This Requirement has been moved into BAL- 002-2 Applicability and "Additional Compliance Information" sections	This requirement does not provide for a reliability outcome and if violated would not cause separation, instability or cascading outages.
BAL-002-0 R2	This requirement has been removed from BAL-002-2	This requirement falls under the Paragraph 81 rules. This requirement defines a commercial agreement between the BA involved in the RSG. This requirement does not provide for a reliability outcome and if violated would not cause separation, instability or cascading outages.
BAL-002-0 R3	Requirement R1 and R2	This requirement was broken apart. The requirement was defining two separate actions; 1) to require activation of Contingency Reserves, and 2) to require having Contingency Reserves equal to its MSSC.
BAL-002-0 R4	This Requirement has been moved into BAL- 002-2 Requirement R1 and into the "Contingency Event Recovery Period" and "Contingency Reserve Restoration Period" definitions.	A portion of this requirement was defining the timing for recovery from an event. This has now been defined and has been proposed to be added to the NERC Glossary of Terms.



Standard: BAL-002-0 – Disturbance Control Standard		
Requirement in	Transitions to the below Requirement in	Description and Change Justification
Approved Standard	New Standard or Other Action	
BAL-002-0 R5	This Requirement has been moved into BAL- 002-2 Requirement R1 and "Reserve Sharing Group Reporting ACE" definition.	A portion of this requirement was defining how a RSG calculates its ACE. This has now been defined and has been proposed to be added to the NERC Glossary of Terms.
BAL-002-0 R6	This Requirement has been moved into the BAL-002-2 Requirement R1 and "Contingency Event Restoration Period" definition.	A portion of this requirement was defining the timing for recovery from an event. This has now been defined and has been proposed to be added to the NERC Glossary of Terms.