

Implementation Plan

Project 2010-14.1 Balancing Authority Reliability-based Controls - Reserves

Implementation Plan for BAL-012-1 – Operating Reserve Planning

Approvals Required

BAL-012-1 – Operating Reserve Planning

Prerequisite Approvals

None

Revisions to Glossary Terms

The following definition shall become effective when BAL-012-1 becomes effective:

Frequency Responsive Reserve: An amount of reserve automatically responsive to local frequency deviation during the primary control time frame.

Applicable Entities

Balancing Authority

Reserve Sharing Group

Applicable Facilities

N/A

Conforming Changes to Other Standards

None

Effective Dates

BAL-012-1 shall become effective as follows:

First day of the first calendar quarter that is 12 months beyond the date that this standard is approved by applicable regulatory authorities, or in those jurisdictions where regulatory approval is not required, the standard becomes effective the first day of the first calendar quarter that is 12 months beyond the date this standard is approved by the NERC Board of Trustees', or as otherwise made pursuant to the laws applicable to such ERO governmental authorities.

Justification

The 12-month period for implementation of BAL-012-1 will provide ample time for Balancing Authorities to develop their reserve plans and implement procedures to comply with this standard.

Retirements

None