

Modifications to TOP and IRO Standards

Jason Smith, Southwest Power Pool
Industry Webinar
July 22, 2016

RELIABILITY | ACCOUNTABILITY



- It is NERC's policy and practice to obey the antitrust laws to avoid all conduct that unreasonably restrains competition. This policy requires the avoidance of any conduct that violates, or that might appear to violate, the antitrust laws. Among other things, the antitrust laws forbid any agreement between or among competitors regarding prices, availability of service, product design, terms of sale, division of markets, allocation of customers or any other activity that unreasonably restrains competition.
- It is the responsibility of every NERC participant and employee who may in any way affect NERC's compliance with the antitrust laws to carry out this commitment.

- Participants are reminded that this meeting is public. Notice of the meeting was posted on the NERC website and widely distributed. Participants should keep in mind that the audience may include members of the press and representatives of various governmental authorities, in addition to the expected participation by industry stakeholders.

- Project 2016-01 background
- Review of proposed changes to IRO-002 and TOP-001
- Next steps
- Questions and answers

- FERC issued Order No. 817 in November 2015 approving revised TOP and IRO Standards and directing modifications
 - Revised TOP and IRO standards become effective in 2017
- Modifications address three objectives:
 - Transmission Operator (TOP) monitoring of some non-BES facilities
 - Redundancy and diverse routing of data exchange capabilities
 - Testing for data exchange capabilities used in primary control centers
- Revisions must be filed by July 2017

- Standards Committee (SC) authorized posting Project 2016-01 SAR in January 2016
- *The SDT shall address each of the Order 817 directives by developing modifications to requirements in TOP-001-3 and IRO-002-4*
- **SAR and Consideration of Comments** are posted on the [project page](#)

- The SDT has developed revisions to IRO-002 and TOP-001 addressing all of the SAR objectives
- Proposed **IRO-002-5 – Reliability Coordination – Monitoring and Analysis** contains revised requirements applicable to Reliability Coordinators (RC)
- Proposed **TOP-001-4 – Transmission Operations** contains revised requirements applicable to TOPs and Balancing Authorities (BA)
- The SDT did not develop revisions to other requirements (not in project scope)

- **Directive:** Modify requirements to address monitoring non-BES facilities within or outside the TOP area as necessary for determining System Operating Limit (SOL) exceedances
 - Addresses potential gap during BES exception processing, or situations where some non-BES facilities should be monitored for reliability purposes
- RC requirements for monitoring non-BES facilities are in approved IRO-002-4 Requirement R3

- R10. Each Transmission Operator shall perform the following for determining System Operating Limit (SOL) exceedances within its Transmission Operator Area:
- 10.1 Monitor Facilities within its Transmission Operator Area;
 - 10.2 Monitor the status of Remedial Action Schemes within its Transmission Operator Area;
 - 10.3 **Monitor non-BES facilities within its Transmission Operator Area identified as necessary by the Transmission Operator;**
 - 10.4 Obtain and utilize status, voltages, and flow data for Facilities outside its Transmission Operator Area identified as necessary by the Transmission Operator;
 - 10.5 Obtain and utilize the status of Remedial Action Schemes outside its Transmission Operator Area identified as necessary by the Transmission Operator; and
 - 10.6 **Obtain and utilize status, voltages, and flow data for non-BES facilities outside its Transmission Operator Area identified as necessary by the Transmission Operator.**

The intent of the requirement is to ensure that all facilities (i.e., BES and non-BES) that can adversely impact reliability are monitored. These facilities should be either designated as part of the BES, or otherwise be incorporated into monitoring when identified by planning and operating studies such as the Operational Planning Analysis required by TOP-002-4 Requirement R1 and IRO-008-2 Requirement R1. The SDT recognizes that not all non-BES facilities that a TOP considers necessary for its monitoring needs will need to be included in the BES.

...

TOP-003-3 Requirement R1 specifies that the TOP shall develop a data specification which includes data and information needed by the TOP to support its Operational Planning Analyses, Real-time monitoring, and Real-time Assessments. This includes non-BES data and external network data as deemed necessary by the TOP.

The format of the proposed requirement has been changed from the approved standard to more clearly indicate which monitoring activities are required to be performed.

- **Directive:** Modify standards to include requirements for redundancy and diverse routing of data exchange capabilities used by RC, TOP, and BA
- Proposed changes to IRO-002 are presented on the following slides
 - Similar requirements for TOP and BA are in proposed TOP-001-4

R2. Each Reliability Coordinator shall have data exchange capabilities, with redundant and diversely routed data exchange infrastructure within the Reliability Coordinator's Control Center, for the exchange of Real-time data with its Balancing Authorities and Transmission Operators, and with other entities it deems necessary, for it to perform its Real-time monitoring and Real-time Assessments.

Redundant and diversely routed data exchange capabilities consist of infrastructure that will provide continued functionality despite failure or malfunction of an individual component within the Reliability Coordinator's Control Center. Requirement R2 does not require automatic or instantaneous fail-over of data exchange capabilities. Redundancy and diverse routing may be achieved in various ways depending on the arrangement of the infrastructure or hardware within the RC Control Center.

Infrastructure that is not within the RC's Control Center is not addressed by this requirement.

- **Directive:** Modify standards to require testing of alternate data exchange capabilities used by RC, TOP, and BA in primary control centers
- Proposed changes to IRO-002 for addressing the Data Exchange Redundancy testing are presented on the following slide
 - Similar requirements for TOP and BA are in proposed TOP-001-4

R3. Each Reliability Coordinator shall test its data exchange capabilities specified in Requirement R2 for redundant functionality at least once each calendar month. If the test is unsuccessful, the Reliability Coordinator shall initiate action within two hours to restore redundant functionality.

Rationale:

- *A test for redundant functionality demonstrates that data exchange capabilities will continue to operate despite the malfunction or failure of an individual component. An entity's testing practices should, over time, examine the various failure modes of its data exchange capabilities. When an actual event successfully exercises the redundant functionality, it can be considered a test for the purposes of the proposed requirement.*

- Proposed implementation period for revised IRO-002 requirements is 3 months following regulatory approval
- Proposed implementation period for revised TOP-001 requirements is 12 months following regulatory approval
 - Longer implementation period is needed due to new requirement for TOPs to monitor some non-BES facilities

- Proposed standards are posted for comment through August 3, 2016
 - Initial ballots and non-binding polls will be conducted July 25 – August 3, 2016
- Draft Reliability Standards Audit Worksheets (RSAWs) are posted for comment
 - Send feedback to RSAWfeedback@nerc.net
- SDT will meet in August 2016 to consider comments and revise drafts
- Revised standards must be filed with FERC by July 2017

- Refer to the [Project 2016-01](#) page for more information
- Jason Smith, SPP, SDT Chair
 - Email at jsmith@spp.org

Chair	Jason Smith	SPP
Vice Chair	David Bueche	CenterPoint
Members	Daniel Hawk	LGE&KU
	Saad Malik	Peak Reliability
	Mark Riley	AECI
	Linwood Ross	Duke Energy
	Joshua Shultz	TVA

- Mark Olson, Senior Standards Developer
 - Email at mark.olson@nerc.net



Questions and Answers