

A. Introduction

1. **Title:** Reliability Coordination – Wide-Area View
2. **Number:** IRO-003-1
3. **Purpose:** The Reliability Coordinator must have a wide area view of its own Reliability Coordinator Area and that of neighboring Reliability Coordinators.
4. **Applicability**
 - 4.1. Reliability Coordinators.
5. **Effective Date:** August 1, 2006

B. Requirements

- R1. Each Reliability Coordinator shall monitor all Bulk Electric System facilities, which may include sub-transmission information, within its Reliability Coordinator Area and adjacent Reliability Coordinator Areas, as necessary to ensure that, at any time, regardless of prior planned or unplanned events, the Reliability Coordinator is able to determine any potential System Operating Limit and Interconnection Reliability Operating Limit violations within its Reliability Coordinator Area.
- R2. Each Reliability Coordinator shall know the current status of all critical facilities whose failure, degradation or disconnection could result in an SOL or IROL violation. Reliability Coordinators shall also know the status of any facilities that may be required to assist area restoration objectives.

C. Measures

Not specified.

D. Compliance

Not specified.

E. Regional Differences

None identified.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata